



FUEL REPORT

Sample Rating Trend

NORMAL



Machine Id
IDEM FODT 6

Component
Diesel Fuel
Fluid
DIESEL FUEL No. 2 (--- GAL)

DIAGNOSIS

Recommendation

ASTM D240 result 19,625 BTU/lb. Test performed at subcontracted ISO 17025 laboratory. All laboratory tests indicate that this sample meets specifications for No.2 low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible. The amount and size of particulates present in the system are acceptable.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			WC0790711	---	---
Sample Date	Client Info			15 Sep 2023	---	---
Machine Age	hrs	Client Info		0	---	---
Sample Status				NORMAL	---	---

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		0.863	---	---
Fuel Color	text	*Visual Screen		Red	---	---
ASTM Color	scalar	*ASTM D1500		L4.0	---	---
Visc @ 40°C	cSt	ASTM D445	4.1	2.6	---	---
Pensky-Martens Flash Point	°C	*PMCC Calculated		59	---	---
Cloud Point	°C	ASTM D5771		-22	---	---
Pour Point	°C	ASTM D5950		-36	---	---

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		2	---	---
Sulfur (UVF)	ppm	ASTM D5453		18	---	---






DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		165	---	---
5% Distillation Point	°C	ASTM D86		190	---	---
10% Distill Point	°C	ASTM D86		205	---	---
15% Distillation Point	°C	ASTM D86		216	---	---
20% Distill Point	°C	ASTM D86		225	---	---
30% Distill Point	°C	ASTM D86		240	---	---
40% Distill Point	°C	ASTM D86		253	---	---
50% Distill Point	°C	ASTM D86		265	---	---
60% Distill Point	°C	ASTM D86		277	---	---
70% Distill Point	°C	ASTM D86		289	---	---
80% Distill Point	°C	ASTM D86		303	---	---
85% Distillation Point	°C	ASTM D86		311	---	---
90% Distill Point	°C	ASTM D86		321	---	---
95% Distillation Point	°C	ASTM D86		338	---	---
Final Boiling Point	°C	ASTM D86		349	---	---
Distillation Residue	%	ASTM D86		1.4	---	---
Distillation Loss	%	ASTM D86		0.7	---	---

IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D7777		32.5	---	---
Cetane Index		ASTM D4737	<40.0	41.0	---	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0	---	---
Sodium	ppm	ASTM D5185m	<0.1	2	---	---
Potassium	ppm	ASTM D5185m	<0.1	0	---	---
Water	%	ASTM D6304	<0.05	0.003	---	---
ppm Water	ppm	ASTM D6304	<500	34.0	---	---
% Gasoline	%	*In-House	<0.50	0.0	---	---
% Biodiesel	%	*In-House	<20.0	0.0	---	---



FUEL REPORT





FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	256	---	---
Particles >6µm	ASTM D7647	>640	66	---	---
Particles >14µm	ASTM D7647	>80	12	---	---
Particles >21µm	ASTM D7647	>20	4	---	---
Particles >38µm	ASTM D7647	>4	0	---	---
Particles >71µm	ASTM D7647	>3	0	---	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	15/13/11	---	---

HEAVY METALS	method	limit/base	current	history1	history2	
Aluminum	ppm	ASTM D5185m	<0.1	<1	---	---
Nickel	ppm	ASTM D5185m	<0.1	0	---	---
Lead	ppm	ASTM D5185m	<0.1	0	---	---
Vanadium	ppm	ASTM D5185m	<0.1	0	---	---
Iron	ppm	ASTM D5185m	<0.1	0	---	---
Calcium	ppm	ASTM D5185m	<0.1	0	---	---
Magnesium	ppm	ASTM D5185m	<0.1	0	---	---
Phosphorus	ppm	ASTM D5185m	<0.1	<1	---	---
Zinc	ppm	ASTM D5185m	<0.1	0	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2	
Color					no image	no image
Bottom					no image	no image

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0790711 **Received** : 25 Sep 2023
Lab Number : 05960263 **Diagnosed** : 02 Oct 2023
Unique Number : 10661476 **Diagnostician** : Doug Bogart
Test Package : DF-3 (Additional Tests: Screen)

PETROLEUM TECHNOLOGIES GROUP
 4665 BROADMOOR AVE, SUITE 150
 GRAND RAPIDS, MI
 US 49512
 Contact: JAMES KRAFT
 james@oil-lab.com
 T: (616)698-9399
 F:

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)