




# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



## Machine Id **ALLIS-CHALMERS U-24 GENERATOR**

Component

**Thrust Bearing**

Fluid

**NOT GIVEN (2000 GAL)**

### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0845041</b>	WC0786727	WC0731014
Sample Date	Client Info		<b>12 Sep 2023</b>	02 Mar 2023	16 Sep 2022
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>NORMAL</b>	NORMAL	NORMAL

### WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >85	<b>&lt;1</b>	<1	0
Chromium	ppm	ASTM D5185m >20	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >20	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	<1
Silver	ppm	ASTM D5185m	<b>0</b>	0	<1
Aluminum	ppm	ASTM D5185m >40	<b>0</b>	<1	<1
Lead	ppm	ASTM D5185m >60	<b>&lt;1</b>	1	0
Copper	ppm	ASTM D5185m >7	<b>2</b>	2	2
Tin	ppm	ASTM D5185m >40	<b>&lt;1</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	<1
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

### ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	0	1
Magnesium	ppm	ASTM D5185m	<b>2</b>	<1	2
Calcium	ppm	ASTM D5185m	<b>40</b>	37	29
Phosphorus	ppm	ASTM D5185m	<b>23</b>	14	30
Zinc	ppm	ASTM D5185m	<b>7</b>	11	7
Sulfur	ppm	ASTM D5185m	<b>310</b>	306	97

### CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >20	<b>1</b>	<1	1
Sodium	ppm	ASTM D5185m	<b>3</b>	0	<1
Potassium	ppm	ASTM D5185m >20	<b>1</b>	<1	0

### FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>303</b>	608	265
Particles >6µm	ASTM D7647	>1300	<b>79</b>	156	46
Particles >14µm	ASTM D7647	>160	<b>7</b>	8	4
Particles >21µm	ASTM D7647	>40	<b>2</b>	2	1
Particles >38µm	ASTM D7647	>10	<b>0</b>	0	0
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>--/17/14	<b>15/13/10</b>	16/14/10	15/13/9


### FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.08</b>	0.172	0.059




# OIL ANALYSIS REPORT


**Particle Trend**




**Acid Number**



**Viscosity @ 40°C**



**Particle Trend**



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	66.8	66.0	66.9

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------






**Color**

**Bottom**

**PrtFilter**

no image      no image      no image

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0845041      **Received** : 25 Sep 2023  
**Lab Number** : 05960565      **Diagnosed** : 27 Sep 2023  
**Unique Number** : 10661778      **Diagnostician** : Don Baldrige  
**Test Package** : PLANT ( Additional Tests: FilterPatch )

**NEW YORK POWER AUTHORITY**  
 PO BOX 700  
 MASSENA, NY  
 US 13662  
 Contact: ANDY WESTMACOTT  
 Andy.Westmacott@nypa.gov  
 T: (315)764-6250  
 F: (315)764-6612

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)