


# **OIL ANALYSIS REPORT**

## Sample Rating Trend







# ALLIS-CHALMERS U-32 GENERATOR

Component

**Thrust Bearing** 

**NOT GIVEN (2000 GAL)** 

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

#### Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

mc2005 Dec2009 Dec2013 Aug/2015 Mar/2017 Aug/2018 Mar/2020 Mar/2022 Sep/201						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0845025	WC0786711	WC0731030
Sample Date		Client Info		13 Sep 2023	03 Mar 2023	16 Sep 2022
Machine Age	yrs	Client Info		0	0	0
Oil Age	yrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>85	<1	<1	<1
Chromium	ppm	ASTM D5185m	>20	0	0	0
Nickel	ppm	ASTM D5185m	>20	0	0	0
Titanium	ppm	ASTM D5185m		0	0	<1
Silver	ppm	ASTM D5185m		0	0	<1
Aluminum	ppm	ASTM D5185m	>40	0	<1	0
Lead	ppm	ASTM D5185m	>60	0	<1	0
Copper	ppm	ASTM D5185m	>7	1	<1	<1
Tin	ppm	ASTM D5185m	>40	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	<1
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		<1	<1	<1
Manganese	ppm	ASTM D5185m		<1	0	1
Magnesium	ppm	ASTM D5185m		<1	<1	1
Calcium	ppm	ASTM D5185m		24	22	15
Phosphorus	ppm	ASTM D5185m		15	8	26
Zinc	ppm	ASTM D5185m		0	<1	0
Sulfur	ppm	ASTM D5185m		6634	5061	6042
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>20	<1	<1	1
Sodium	ppm	ASTM D5185m		3	0	<1
Potassium	ppm	ASTM D5185m	>20	1	1	0
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1364	314	1771
Particles >6µm		ASTM D7647	>1300	401	75	368
Particles >14μm		ASTM D7647	>160	25	5	27
Particles >21µm		ASTM D7647	>40	4	0	5
Particles >38μm		ASTM D7647	>10	0	0	0
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/14	18/16/12	15/13/10	18/16/12
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

Acid Number (AN) mg KOH/g ASTM D8045

0.175

0.084

0.065



## **OIL ANALYSIS REPORT**







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** 

: 05960581 : 10661794

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : WC0845025 Diagnosed

Diagnostician : Don Baldridge Test Package : PLANT ( Additional Tests: FilterPatch )

: 25 Sep 2023

: 27 Sep 2023

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**NEW YORK POWER AUTHORITY** 

**PO BOX 700** MASSENA, NY US 13662

Contact: ANDY WESTMACOTT Andy.Westmacott@nypa.gov

T: (315)764-6250 F: (315)764-6612

Contact/Location: ANDY WESTMACOTT - NEWMAS