



## **PROBLEM SUMMARY**



## Machine Id 7213970 (S/N 1553) Component

Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS						
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL	
Particles >6µm	ASTM D7647	>1300	<b>A</b> 3628	<u> </u>		
Particles >14µm	ASTM D7647	>80	<u> </u>	<b>4</b> 60		
Oil Cleanliness	ISO 4406 (c)	>/17/13	<u> </u>	<u> </u>		

Customer Id: CARHAN Sample No.: KCPA006171 Lab Number: 05960605 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Angela Borella +1 800-237-1369 angela.borella@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

#### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

### **HISTORICAL DIAGNOSIS**

## 18 May 2022 Diag: Jonathan Hester



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


#### 15 Mar 2021 Diag: Angela Borella



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report



## Report Id: CARHAN [WUSCAR] 05960605 (Generated: 09/27/2023 13:25:30) Rev: 1



## **OIL ANALYSIS REPORT**

SAMPLE INFORMATION method limit/base

# Sample Rating Trend ISO ISO ISO

current

history1

history2

Machine Id 7213970 (S/N 1553) Component

**Compressor** 

KAESER SIGMA (OEM) M-460 (--- GAL)

## DIAGNOSIS

## Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

## Wear

All component wear rates are normal.

## Contamination

There is a high amount of particulates present in the oil.

## Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	/IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA006171	KCP51378	KCP27728
Sample Date		Client Info		06 Sep 2023	18 May 2022	15 Mar 2021
Machine Age	hrs	Client Info		4630	3067	1373
Oil Age	hrs	Client Info		0	1694	1373
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m		<1	2	0
Lead	ppm	ASTM D5185m	>10	0	<1	<1
Copper	ppm	ASTM D5185m		4	2	1
Tin	ppm	ASTM D5185m	>10	- <1	<1	0
Antimony	ppm	ASTM D5185m	~10			0
Vanadium		ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
Gaumum	ppm	ASTIVI DOTODIII		U	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	<1	<1
Barium	ppm	ASTM D5185m	90	<1	0	6
Molybdenum	ppm	ASTM D5185m	0	<1	0	0
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m	100	54	73	71
Calcium	ppm	ASTM D5185m	0	2	<1	0
Phosphorus	ppm	ASTM D5185m	0	5	5	<1
Zinc	ppm	ASTM D5185m	0	0	3	0
Sulfur	ppm	ASTM D5185m	23500	24866	18596	15936
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	<1
Sodium	ppm	ASTM D5185m		9	18	11
Potassium	ppm	ASTM D5185m	>20	3	7	6
Water	%	ASTM D6304	>0.05	0.031	0.034	0.041
ppm Water	ppm	ASTM D6304	>500	313.0	342.3	412.0
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		8883	18370	
Particles >6µm		ASTM D7647	>1300	<b>A</b> 3628	▲ 7425	
Particles >14µm		ASTM D7647	>80	<u> </u>	<u> </u>	
Particles >21µm		ASTM D7647	>20	22	<b>1</b> 30	
Particles >38µm		ASTM D7647	>4	0	<b>5</b>	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>A</b> 20/19/15	▲ 21/20/16	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g			0.40	0.38	0.385
25:30) Rev: 1	ing NOTing	70 FW D0043	1.0		on: Service Man	


Report Id: CARHAN [WUSCAR] 05960605 (Generated: 09/27/2023 13:25:30) Rev: 1


Contact/Location: Service Manager - CARHAN



## **OIL ANALYSIS REPORT**








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	LIGHT	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	🔺 MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	50.1	47.5	44.3
SAMPLE IMAGES	6	method	limit/base	current	history1	history2
Color				•		

Bottom



Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: Service Manager - CARHAN