

PROBLEM SUMMARY

Sample Rating Trend




2473970 (S/N 1025)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

| PROBLEMATIC TEST RESULTS | | | | | | | | | |
|--------------------------|--------------|---------|-----------------|----------------|----------|--|--|--|--|
| Sample Status | | | ABNORMAL | ABNORMAL | ABNORMAL | | | | |
| Particles >6µm | ASTM D7647 | >1300 | 18810 | <u>▲</u> 5274 | | | | | |
| Particles >14μm | ASTM D7647 | >80 | 1553 | 41 | | | | | |
| Particles >21µm | ASTM D7647 | >20 | <u> </u> | 5 | | | | | |
| Oil Cleanliness | ISO 4406 (c) | >/17/13 | 23/21/18 | <u>^</u> 20/13 | | | | | |

Customer Id: ACAROS Sample No.: KCP49632 Lab Number: 05960607 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Angela Borella +1 800-237-1369 angela.borella@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|---------------|--------|------|---------|---|
| Change Fluid | | | ? | Oil and filter change at the time of sampling has been noted. |
| Change Filter | | | ? | Oil and filter change at the time of sampling has been noted. |

HISTORICAL DIAGNOSIS

16 Jul 2021 Diag: Don Baldridge

WEAR



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. The aluminum level is abnormal. All other component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



23 Apr 2021 Diag: Don Baldridge

VIS DEBRIS




No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



ISO

2473970 (S/N 1025)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| | | AprŽ021 | | Jul2021 Aug2023 | | |
|-----------------|--------|--------------|------------|-------------------|----------------|-------------|
| SAMPLE INFORM | MATION | method | limit/base | current | history1 | history2 |
| Sample Number | | Client Info | | KCP49632 | KCP23009 | KCP35624 |
| Sample Date | | Client Info | | 31 Aug 2023 | 16 Jul 2021 | 23 Apr 2021 |
| Machine Age | hrs | Client Info | | 3708 | 0 | 46587 |
| Oil Age | hrs | Client Info | | 0 | 0 | 3365 |
| Oil Changed | | Client Info | | Changed | Changed | Changed |
| Sample Status | | | | ABNORMAL | ABNORMAL | ABNORMAL |
| WEAR METALS | | method | limit/base | current | history1 | history2 |
| Iron | ppm | ASTM D5185m | >50 | <1 | 6 | <1 |
| Chromium | ppm | ASTM D5185m | >10 | 0 | <1 | 0 |
| Nickel | ppm | ASTM D5185m | >3 | 0 | 0 | <1 |
| Titanium | ppm | ASTM D5185m | >3 | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m | >2 | <1 | <1 | 0 |
| Aluminum | ppm | ASTM D5185m | >10 | 6 | <u> 16</u> | <1 |
| Lead | ppm | ASTM D5185m | >10 | 0 | 0 | 0 |
| Copper | ppm | | >50 | 6 | 8 | <1 |
| Tin | ppm | ASTM D5185m | >10 | 4 | 3 | 4 |
| Antimony | ppm | ASTM D5185m | | | 0 | 0 |
| Vanadium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | 0 | 0 | <1 | <1 |
| Barium | ppm | ASTM D5185m | 90 | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185m | 0 | <1 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | | <1 | <1 | 0 |
| Magnesium | ppm | ASTM D5185m | 100 | 3 | 11 | <1 |
| Calcium | ppm | ASTM D5185m | 0 | 1 | 0 | 0 |
| Phosphorus | ppm | ASTM D5185m | 0 | 7 | 16 | 22 |
| Zinc | ppm | ASTM D5185m | 0 | 6 | 2 | 0 |
| Sulfur | ppm | ASTM D5185m | 23500 | 22798 | 12305 | 461 |
| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >25 | <1 | <1 | 0 |
| Sodium | ppm | ASTM D5185m | | 4 | 2 | <1 |
| Potassium | ppm | ASTM D5185m | >20 | 2 | 2 | <1 |
| Water | % | ASTM D6304 | >0.05 | 0.010 | 0.012 | 0.010 |
| ppm Water | ppm | ASTM D6304 | >500 | 108.8 | 125.2 | 106.1 |
| FLUID CLEANLIN | ESS | method | limit/base | current | history1 | history2 |
| Particles >4µm | | ASTM D7647 | | 46488 | 52521 | |
| Particles >6µm | | ASTM D7647 | >1300 | 18810 | <u>▲</u> 5274 | |
| Particles >14μm | | ASTM D7647 | >80 | <u> </u> | 41 | |
| Particles >21μm | | ASTM D7647 | >20 | <u>^</u> 272 | 5 | |
| Particles >38μm | | ASTM D7647 | >4 | 2 | 0 | |
| Particles >71μm | | ASTM D7647 | >3 | 0 | 0 | |
| Oil Cleanliness | | ISO 4406 (c) | >/17/13 | <u>^</u> 23/21/18 | △ 20/13 | |
| FLUID DEGRADA | TION | method | limit/base | current | history1 | history2 |
| | | | | | | |

Acid Number (AN)

mg KOH/g ASTM D8045 1.0


0.428 0.302

Report Id: ACAROS [WUSCAR] 05960607 (Generated: 09/27/2023 13:18:52) Rev: 1

Contact/Location: Service Manager - ACAROS



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number**

: KCP49632

: 05960607 : 10661820

Received Diagnosed

: 27 Sep 2023 Diagnostician : Angela Borella

Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

930 TODDS LN ROSEDALE, MD US 21237

Contact: Service Manager

T: F: