




Machine Id 7213969 (S/N 1552) Component

Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL		
Particles >6µm	ASTM D7647	>1300	<u> </u>	▲ 3835	A 7981		
Particles >14µm	ASTM D7647	>80	🔺 277	4 298	A 753		
Particles >21µm	ASTM D7647	>20	<u> </u>	4 7	1 80		
Oil Cleanliness	ISO 4406 (c)	>/17/13	A 20/19/15	🔺 21/19/15	2 0/17		


Customer Id: CARHAN Sample No.: KCPA006080 Lab Number: 05960631 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

18 May 2022 Diag: Angela Borella



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

15 Mar 2021 Diag: Jonathan Hester



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report



OIL ANALYSIS REPORT

SAMPLE INFORMATION method

Sample Rating Trend ISO

current

history1

history2

Machine Id 7213969 (S/N 1552) Component

Compressor

Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMIFLE INFURIN	ATION	method	iimi/base	current	nistory i	nistory2
Sample Number		Client Info		KCPA006080	KCP51377	KCP27727
Sample Date		Client Info		06 Sep 2023	18 May 2022	15 Mar 2021
Machine Age	hrs	Client Info		4871	3368	1612
Oil Age	hrs	Client Info		0	2124	1612
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	1	<1
Aluminum	ppm	ASTM D5185m	>10	<1	1	<1
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	4	3	1
Tin	ppm	ASTM D5185m	>10	<1	0	<1
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	<1	8
Barium	ppm	ASTM D5185m	90	<1	<1	7
Molybdenum	ppm	ASTM D5185m	0	<1	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	100	57	76	64
Calcium	ppm	ASTM D5185m	0	1	0	1
Phosphorus	ppm	ASTM D5185m	0	4	11	3
Zinc	ppm	ASTM D5185m	0	0	7	3
Sulfur	ppm	ASTM D5185m	23500	25689	19258	13197
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	0
Sodium	ppm	ASTM D5185m		11	20	15
Potassium	ppm	ASTM D5185m	>20	4	<1	5
Water	%	ASTM D6304	>0.05	0.026	0.036	0.021
ppm Water	ppm	ASTM D6304	>500	260.6	369.0	213.0
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		8439	10742	18872
Particles >6µm		ASTM D7647	>1300	<u> </u>	A 3835	A 7981
Particles >14µm		ASTM D7647	>80	<u> </u>	<u> </u>	1 753
Particles >21µm		ASTM D7647	>20	<u> </u>	4 7	<u> </u>
Particles >38µm		ASTM D7647	>4	3	1	2
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	A 20/19/15	1 21/19/15	2 0/17
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.40	0.35	0.351
00.05) D				0	0	


limit/base


Report Id: CARHAN [WUSCAR] 05960631 (Generated: 09/29/2023 10:20:25) Rev: 1


Contact/Location: Service Manager - CARHAN



OIL ANALYSIS REPORT








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	LIGHT	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	52.15	49.0	44.4
SAMPLE IMAGES	6	method	limit/base	current	history1	history2
Color						

Bottom



* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)