

# **PROBLEM SUMMARY**

Sample Rating Trend




KAESER 7376028

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

# **COMPONENT CONDITION SUMMARY**



# RECOMMENDATION

There is too much water present in this sample to perform a particle count. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS												
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL						
Water	%	ASTM D6304	>0.05	<b>△</b> 0.198	<b>△</b> 0.132	<b>△</b> 0.209						
ppm Water	mqq	ASTM D6304	>500	<b>1980</b>	▲ 1323.6	<u>^</u> 2090						

Customer Id: MENNEE Sample No.: KCPA006424 Lab Number: 05960640 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Angela Borella +1 800-237-1369 angela.borella@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

# **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

# HISTORICAL DIAGNOSIS

# 11 Dec 2021 Diag: Angela Borella

#### WATER



Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



# 22 Sep 2020 Diag: Angela Borella

#### WATER



The filter change at the time of sampling has been noted. All component wear rates are normal. There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

Sample Rating Trend



**WATER** 



# **KAESER 7376028**

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

# **DIAGNOSIS**

## Recommendation

There is too much water present in this sample to perform a particle count. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

All component wear rates are normal.

## Contamination

There is a moderate concentration of water present in the oil.

## **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

		Sep	2020	Dec2021 Sep203	23	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA006424	KC95137	KC72787
Sample Date		Client Info		20 Sep 2023	11 Dec 2021	22 Sep 2020
Machine Age	hrs	Client Info		28482	13202	3060
Oil Age	hrs	Client Info		0	6958	3060
Oil Changed		Client Info		N/A	Changed	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	<1	<1
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	13	12	3
Tin	ppm	ASTM D5185m	>10	<1	<1	<1
Antimony	ppm	ASTM D5185m			0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	17	<1
Barium	ppm	ASTM D5185m	90	0	0	5
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m	90	12	2	34
Calcium	ppm	ASTM D5185m	2	1	0	<1
Phosphorus	ppm	ASTM D5185m		3	2	7
Zinc	ppm	ASTM D5185m		13	3	0
Sulfur	ppm	ASTM D5185m		21293	15230	15253
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	2
Sodium	ppm	ASTM D5185m		5	2	10
Potassium	ppm	ASTM D5185m	>20	1	0	3
Water	%	ASTM D6304	>0.05	<u> </u>	<b>△</b> 0.132	△ 0.209
ppm Water	ppm	ASTM D6304	>500	<u> </u>	▲ 1323.6	△ 2090
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647				1733
Particles >6µm		ASTM D7647	>1300			944
Particles >14μm		ASTM D7647	>80			<u> </u>
Particles >21µm		ASTM D7647	>20			<u></u> ▲ 54
Particles >38μm		ASTM D7647	>4			<u> 8</u>
Particles >71μm		ASTM D7647	>3			1
Oil Cleanliness		ISO 4406 (c)	>/17/13			<b>△</b> 17/15
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2

0.25



# **OIL ANALYSIS REPORT**







Laboratory Sample No. Lab Number **Unique Number** 

: 05960640 : 10661853

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : KCPA006424 Diagnosed

: 25 Sep 2023 : 27 Sep 2023 Diagnostician : Angela Borella Test Package : IND 2 ( Additional Tests: KF, PrtCount )

225 BROOKS AVE NEENAH, WI US 54956 Contact: Service Manager

**MENASHA PACKAGING** 

SERVICE@NORTHERNCOMPRESSOR.COM To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: