


PROBLEM SUMMARY

Sample Rating Trend



VISCOSITY




Machine Id
KAESER SM 10 4948114 (S/N 1657)

Component
Compressor


Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Viscosity @ 40°C



▲ Particle Trend



RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	ABNORMAL
Particles >6µm	ASTM D7647	>1300	▲ 8584	---	▲ 3900
Particles >14µm	ASTM D7647	>80	▲ 553	---	▲ 343
Particles >21µm	ASTM D7647	>20	▲ 155	---	▲ 111
Particles >38µm	ASTM D7647	>4	▲ 12	---	▲ 6
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ 22/20/16	---	▲ 19/16
Visc @ 40°C	cSt	ASTM D445	45	▲ 56.7	▲ 53.6

Customer Id: FEDMID
Sample No.: KCPA004772
Lab Number: 05960651
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Angela Borella +1 800-237-1369
angela.borella@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

20 Jul 2021 Diag: Angela Borella

VISCOSITY



Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

view report



11 Jan 2021 Diag: Don Baldrige

VISCOSITY



Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

view report



18 Jun 2020 Diag: Jonathan Hester

VISCOSITY




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



VISCOSITY



Machine Id
KAESER SM 10 4948114 (S/N 1657)

Component
Compressor
Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

▲ Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

▲ Contamination

There is a high amount of particulates present in the oil.

▲ Fluid Condition

The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			KCPA004772	KCP42516	KCP31799
Sample Date	Client Info			31 Aug 2023	20 Jul 2021	11 Jan 2021
Machine Age	hrs	Client Info		55813	43304	39843
Oil Age	hrs	Client Info		0	3000	3267
Oil Changed	Client Info			N/A	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	<1	<1
Aluminum	ppm	ASTM D5185m	>10	0	1	0
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	9	7	9
Tin	ppm	ASTM D5185m	>10	<1	0	0
Antimony	ppm	ASTM D5185m		---	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	<1	<1
Barium	ppm	ASTM D5185m	90	0	0	<1
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	100	3	16	27
Calcium	ppm	ASTM D5185m	0	<1	0	0
Phosphorus	ppm	ASTM D5185m	0	5	9	2
Zinc	ppm	ASTM D5185m	0	14	11	55
Sulfur	ppm	ASTM D5185m	23500	23325	19593	18687

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2	<1	2
Sodium	ppm	ASTM D5185m		5	4	30
Potassium	ppm	ASTM D5185m	>20	1	<1	6
Water	%	ASTM D6304	>0.05	0.004	0.016	0.010
ppm Water	ppm	ASTM D6304	>500	43.1	164.9	107.5

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		30076	---	12494
Particles >6µm		ASTM D7647	>1300	▲ 8584	---	▲ 3900
Particles >14µm		ASTM D7647	>80	▲ 553	---	▲ 343
Particles >21µm		ASTM D7647	>20	▲ 155	---	▲ 111
Particles >38µm		ASTM D7647	>4	▲ 12	---	▲ 6
Particles >71µm		ASTM D7647	>3	▲ 1	---	0
Oil Cleanliness		ISO 4406 (c)	>--/17/13	▲ 22/20/16	---	▲ 19/16

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.57	0.428	0.490


OIL ANALYSIS REPORT








PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	56.7	53.6

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA004772
Lab Number : 05960651
Unique Number : 10661864
Test Package : IND 2 (Additional Tests: KF, PrtCount)

FEDEX
 2030 N UNION ST
 MIDDLETOWN, PA
 US 17057
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)