


PROBLEM SUMMARY

Machine Id 4393289 (S/N 1177) Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL						
Water	%	ASTM D6304	>0.05	A 0.103	0.018						
ppm Water	ppm	ASTM D6304	>500	<u> </u>	181.5						
Particles >6µm		ASTM D7647	>1300	A 3692							
Oil Cleanliness		ISO 4406 (c)	>/17/13	A 22/19/12							


Customer Id: BKMNEW Sample No.: KCPA006227 Lab Number: 05960663 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

19 May 2021 Diag: Don Baldridge

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend

WATER

Machine Id 4393289 (S/N 1177) Component

Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORM		method	limit/base	current	history1	history2
			minubase			
Sample Number		Client Info		KCPA006227	KCP36590	
Sample Date		Client Info		21 Sep 2023	19 May 2021	
Machine Age	hrs	Client Info		27186	21134	
Oil Age	hrs	Client Info		0	2000	
Oil Changed		Client Info		N/A	Changed	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	<1	<1	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	<1	
Lead	ppm	ASTM D5185m	>10	0	2	
Copper	ppm	ASTM D5185m	>50	14	8	
Tin	ppm	ASTM D5185m	>10	<1	0	
Antimony	ppm	ASTM D5185m	-		0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
	ppm			-		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	24	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m	0	<1	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m	100	4	7	
Calcium	ppm	ASTM D5185m	0	<1	0	
Phosphorus	ppm	ASTM D5185m	0	3	<1	
Zinc	ppm	ASTM D5185m	0	0	11	
Sulfur	ppm	ASTM D5185m	23500	24888	21210	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	3	11	
Sodium	ppm	ASTM D5185m	220	4	3	
Potassium	ppm	ASTM D5185m	>20	2	0	
Water	%	ASTM D518511		∠ ▲ 0.103	0.018	
ppm Water	7 ₀	ASTM D6304 ASTM D6304	>0.05	▲ 1030	181.5	
						history O
FLUID CLEANLIN	200	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	. 1200	23239		
Particles >6µm		ASTM D7647		A 3692		
Particles >14µm		ASTM D7647	>80	36		
Particles >21µm		ASTM D7647		6		
Particles >38µm		ASTM D7647	>4	1		
Particles >71µm		ASTM D7647		0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	A 22/19/12		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.39	0.391	
·50·40) Bov: 1				Contact/Lo	cation: LAFELF	

Report Id: BKMNEW [WUSCAR] 05960663 (Generated: 09/29/2023 07:59:49) Rev: 1

0.391 Contact/Location: J AFFLECK - BKMNEW

Page 3 of 4



12000

10000

800 Water (ppm)

600

400

2000

25

Ê 20

8 15

0

25

Ê 20

10

01

1.20

(^{B/HO)}

Ê 0.72

Ê 0 48

Pio Qcid

0.00

60

55

ပ္ 5(


-73 45

40

35

of nart 10

OIL ANALYSIS REPORT



BK MILL & FIXTURES INC 37523 SYCAMORE ST NEWARK, CA US 94560 Contact: J AFFLECK JAFFLECK@BKMILL.COM T: F:

Certificate L2367

Lab Number

Unique Number

: 05960663

: 10661876

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Test Package : IND 2 (Additional Tests: KF, PrtCount)

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Diagnosed

214

28

history1

NONE

NONE

NONE

NONE

MODER

NONE

NORML

NORML

history

history1

NFG

NEG

48.4

current

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

curren

current

Particle Count

Acid Number

Mav1

: 28 Sep 2023

Diagnostician : Doug Bogart

31

0.2%

NEG

49.0

history2

history

history2

no image

no image

4406

:1999 Cle

14