




PROBLEM SUMMARY

Sample Rating Trend



ISO




Machine Id
4234495 (S/N 1057)

Component
Compressor
Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

| Sample Status | | | ABNORMAL | NORMAL | ABNORMAL |
|-----------------|--------------|-----------|------------|--------|----------|
| Particles >6µm | ASTM D7647 | >1300 | ▲ 50860 | 520 | --- |
| Particles >14µm | ASTM D7647 | >80 | ▲ 3918 | 43 | --- |
| Particles >21µm | ASTM D7647 | >20 | ▲ 853 | 16 | --- |
| Particles >38µm | ASTM D7647 | >4 | ▲ 21 | 1 | --- |
| Oil Cleanliness | ISO 4406 (c) | >--/17/13 | ▲ 24/23/19 | 16/13 | --- |

Customer Id: GIBMTG
Sample No.: KCPA006149
Lab Number: 05960667
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Angela Borella +1 800-237-1369
angela.borella@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

29 Jul 2021 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



21 Jan 2021 Diag: Jonathan Hester

WATER



Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. There is a light concentration of water present in the oil. There is a moderate amount of visible silt present in the sample. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



18 May 2020 Diag: Jonathan Hester

WATER




Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition. Please note that there was too much water present in the oil to perform a viscosity test. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Free water present. There is a light concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
4234495 (S/N 1057)

Component
Compressor
Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

▲ Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

▲ Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| SAMPLE INFORMATION | | method | limit/base | current | history1 | history2 |
|--------------------|-------------|-------------|------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | | KCPA006149 | KCP42670 | KCP27812 |
| Sample Date | Client Info | | | 20 Sep 2023 | 29 Jul 2021 | 21 Jan 2021 |
| Machine Age | hrs | Client Info | | 64813 | 54265 | 50180 |
| Oil Age | hrs | Client Info | | 0 | 3000 | 6000 |
| Oil Changed | Client Info | | | N/A | Changed | Changed |
| Sample Status | | | | ABNORMAL | NORMAL | ABNORMAL |

| WEAR METALS | | method | limit/base | current | history1 | history2 |
|-------------|-----|-------------|------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185m | >50 | <1 | 0 | 2 |
| Chromium | ppm | ASTM D5185m | >10 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m | >3 | 0 | 0 | 0 |
| Titanium | ppm | ASTM D5185m | >3 | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m | >2 | 0 | 0 | <1 |
| Aluminum | ppm | ASTM D5185m | >10 | <1 | 0 | 0 |
| Lead | ppm | ASTM D5185m | >10 | 0 | 0 | <1 |
| Copper | ppm | ASTM D5185m | >50 | 3 | 6 | 7 |
| Tin | ppm | ASTM D5185m | >10 | <1 | 0 | 0 |
| Antimony | ppm | ASTM D5185m | | --- | 0 | 0 |
| Vanadium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | | 0 | <1 | 0 |






| ADDITIVES | | method | limit/base | current | history1 | history2 |
|------------|-----|-------------|------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185m | | 0 | 0 | <1 |
| Barium | ppm | ASTM D5185m | 90 | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185m | | <1 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | | <1 | 0 | <1 |
| Magnesium | ppm | ASTM D5185m | 90 | 70 | 19 | 14 |
| Calcium | ppm | ASTM D5185m | 2 | 1 | 0 | 22 |
| Phosphorus | ppm | ASTM D5185m | | 6 | 17 | 80 |
| Zinc | ppm | ASTM D5185m | | 9 | 41 | 109 |
| Sulfur | ppm | ASTM D5185m | | 21324 | 14713 | 14082 |

| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
|--------------|-----|-------------|------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185m | >25 | 1 | 0 | 0 |
| Sodium | ppm | ASTM D5185m | | 8 | 10 | 7 |
| Potassium | ppm | ASTM D5185m | >20 | 6 | 1 | 2 |
| Water | % | ASTM D6304 | >0.05 | 0.023 | 0.017 | ▲ 0.208 |
| ppm Water | ppm | ASTM D6304 | >500 | 233.5 | 171.7 | ▲ 2080 |

| FLUID CLEANLINESS | | method | limit/base | current | history1 | history2 |
|-------------------|--|--------------|------------|-------------------|----------|----------|
| Particles >4µm | | ASTM D7647 | | 119051 | 1978 | --- |
| Particles >6µm | | ASTM D7647 | >1300 | ▲ 50860 | 520 | --- |
| Particles >14µm | | ASTM D7647 | >80 | ▲ 3918 | 43 | --- |
| Particles >21µm | | ASTM D7647 | >20 | ▲ 853 | 16 | --- |
| Particles >38µm | | ASTM D7647 | >4 | ▲ 21 | 1 | --- |
| Particles >71µm | | ASTM D7647 | >3 | 2 | 0 | --- |
| Oil Cleanliness | | ISO 4406 (c) | >--/17/13 | ▲ 24/23/19 | 16/13 | --- |

| FLUID DEGRADATION | | method | limit/base | current | history1 | history2 |
|-------------------|----------|------------|------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.4 | 0.39 | 0.273 | 0.247 |


OIL ANALYSIS REPORT







| PARAMETER | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | ▲ MODER |
| Debris | scalar | *Visual | NONE | NONE | ▲ MODER |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.05 | NEG | 0.2% |
| Free Water | scalar | *Visual | | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|--------------|---------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 46 | 46.1 | 45.8 | 48.1 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA006149 **Received** : 25 Sep 2023
Lab Number : 05960667 **Diagnosed** : 27 Sep 2023
Unique Number : 10661880 **Diagnostician** : Angela Borella
Test Package : IND 2 (Additional Tests: KF, PrtCount)

GIBALTAR PACKAGING INC - PAPERWORKS
 5465 NC HWY 73 W
 MT GILEAD, NC
 US 27306
 Contact: Service Manager

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: