

PROBLEM SUMMARY

Sample Rating Trend

ISO


Machine Id **6392299 (S/N 1246)**

Component

Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS										
Sample Status			ATTENTION	ABNORMAL						
Particles >6µm	ASTM D7647	>1300	1469							
Particles >14µm	ASTM D7647	>80	<u> </u>							
Particles >21µm	ASTM D7647	>20	<u>^</u> 25							
Oil Cleanliness	ISO 4406 (c)	>/17/13	20/18/14							

Customer Id: BRAEASMA Sample No.: KCPA003515 Lab Number: 05960683 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

23 Jul 2021 Diag: Doug Bogart

ADDITIVES




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. Additive levels indicate the addition of a different brand, or type of oil. Confirm oil type. The AN level is acceptable for this fluid.





OIL ANALYSIS REPORT

Sample Rating Trend



6392299 (S/N 1246)

Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jul2021	Aug2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
					KCP42055	
Sample Number		Client Info		KCPA003515		
Sample Date	bro	Client Info		30 Aug 2023	23 Jul 2021	
Machine Age	hrs	Client Info		40539	24220	
Oil Age	hrs	Client Info		0 N/A	10885	
Oil Changed Sample Status		Ciletit iiiio		ATTENTION	Changed ABNORMAL	
				-		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m		3	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	<1	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	5	1	
Lead	ppm	ASTM D5185m	>10	0	<1	
Copper	ppm	ASTM D5185m	>50	10	9	
Tin	ppm	ASTM D5185m	>10	<1	0	
Antimony	ppm	ASTM D5185m			<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		<1	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m		3	2	
Calcium	ppm	ASTM D5185m		<1	0	
Phosphorus	ppm	ASTM D5185m	500	221	<u> </u>	
Zinc	ppm	ASTM D5185m		258	<u></u> 104	
Sulfur	ppm	ASTM D5185m		1046	▲ 847	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		5	<1	
Potassium	ppm	ASTM D5185m	>20	3	1	
Water	%	ASTM D6304	>0.05	0.002	0.044	
ppm Water	ppm	ASTM D6304	>500	21.4	445.0	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		5034		
Particles >6µm		ASTM D7647	>1300	<u> </u>		
Particles >14μm		ASTM D7647	>80	<u>^</u> 92		
Particles >21µm		ASTM D7647	>20	<u>^</u> 25		
Particles >38µm		ASTM D7647	>4	3		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>△</u> 20/18/14		
FLUID DEGRADA	TION	method	limit/base		history1	history2
				current		

0.377



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number**

: KCPA003515 : 05960683 : 10661896

Received Diagnosed

: 25 Sep 2023 Diagnostician : Jonathan Hester

: 27 Sep 2023 Test Package : IND 2 (Additional Tests: KF, PrtCount)

EAST WEYMOUTH, MA US 02189 Contact: S GOUPIL

SGOUPIL@BRADYENTERPRISES.COM

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: