

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id **1643886 (S/N 1144)** Component

Compressor Fluid

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			0ct2022	Aug2023		
SAMPLE INFORM	NATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA004455	KCP46751	
Sample Date		Client Info		17 Aug 2023	24 Oct 2022	
Machine Age	hrs	Client Info		84717	81636	
Oil Age	hrs	Client Info		0	0	
Oil Changed	1110	Client Info		N/A	Changed	
Sample Status				NORMAL	ATTENTION	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	10	
Chromium	ppm	ASTM D5185m	>10	0	1	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	<1	
Silver	ppm	ASTM D5185m	>2	0	<1	
Aluminum	ppm	ASTM D5185m	>10	0	5	
Lead	ppm	ASTM D5185m	>10	0	2	
Copper	ppm	ASTM D5185m	>50	4	2	
Tin	ppm	ASTM D5185m	>10	<1	1	
Vanadium	ppm	ASTM D5185m		0	<1	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	129	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m		<1	86	
Manganese	ppm	ASTM D5185m		<1	1	
Magnesium	ppm	ASTM D5185m	90	36	62	
Calcium	ppm	ASTM D5185m	2	<1	3342	
Phosphorus	ppm	ASTM D5185m		3	1252	
Zinc	ppm	ASTM D5185m		0	1599	
Sulfur	ppm	ASTM D5185m		20496	5212	
CONTAMINANTS	8	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	4	
Sodium	ppm	ASTM D5185m		15	4	
Potassium	ppm	ASTM D5185m	>20	2	4	
Water	%	ASTM D6304	>0.05	0.015	0.003	
ppm Water	ppm	ASTM D6304	>500	157.4	29.9	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1604	9304	
Particles >6µm		ASTM D7647	>1300	325	1 742	
Particles >14µm		ASTM D7647	>80	23	79	
Particles >21µm		ASTM D7647	>20	5	13	
Particles >38µm		ASTM D7647	>4	1	1	
Particles >71µm		ASTM D7647	>3	1	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/16/12	a 20/18/13	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.35	0.30	



OIL ANALYSIS REPORT



*Visual NONE NONE NONE *Visua NONE NONE NONE scalar *Visual NONE NONE NONE NONE *Visual NONE VLITE NONE *Visual NONE NONE NORML *Visual NORML NORML *Visual NORML NORML NORML *Visual >0.05 NEG NEG scalar *Visual NEG NEG ASTM D445 46 44.3 44.2 no image no image Particle Count 491,52 122,880 30.720 7,680 4406 1,920 per :1999 Cle 480 120 14 31 Aug 17/2: 214 28

Acid Number

(^{0.50} (⁰/HOX)

Ē 0.30

e 0.20

Acid

Aug17/23 -

: 25 Sep 2023

: 27 Sep 2023

0.10

0.00

NONE

LIGHT

NONE

MARSHALLS DISTRIBUTION CENTER 2760 RED LION RD PHILADELPHIA, PA US 19114 Contact: MILAGROS TORRES MILAGROS_TORRES@TJX.COM T: F:

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)