




PROBLEM SUMMARY

Sample Rating Trend

ISO




Machine Id
277 40HP (S/N CBV299282)
 Component
Air Compressor
 Fluid
ULTRA COOLANT 10W20 (--- GAL)



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ATTENTION	ATTENTION	ATTENTION
Particles >6µm	ASTM D7647	>2500	▲ 3080	▲ 3788	708
Particles >14µm	ASTM D7647	>320	▲ 529	▲ 603	173
Particles >21µm	ASTM D7647	>80	▲ 143	▲ 168	49
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ 20/19/16	▲ 20/19/16	18/17/15

Customer Id: CARSALNY
 Sample No.: USPM17939
 Lab Number: 05960693
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

02 Jun 2023 Diag: Doug Bogart

ISO



Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



09 Feb 2023 Diag: Doug Bogart

ADDITIVES



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. Additive levels indicate the addition of a different brand or type of oil. Confirm oil type. The AN level is acceptable for this fluid.

view report



11 Jul 2022 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
277 40HP (S/N CBV299282)

Component
Air Compressor

Fluid
ULTRA COOLANT 10W20 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	USPM17939	USPM17938	USPM17937
Sample Date	Client Info	15 Sep 2023	02 Jun 2023	09 Feb 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ATTENTION	ATTENTION	ATTENTION

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>50	0	0
Chromium	ppm	ASTM D5185m	>4	0	0
Nickel	ppm	ASTM D5185m	>4	0	0
Titanium	ppm	ASTM D5185m		0	0
Silver	ppm	ASTM D5185m		0	0
Aluminum	ppm	ASTM D5185m	>10	0	0
Lead	ppm	ASTM D5185m	>20	0	0
Copper	ppm	ASTM D5185m	>40	<1	0
Tin	ppm	ASTM D5185m	>5	<1	<1
Vanadium	ppm	ASTM D5185m		0	0
Cadmium	ppm	ASTM D5185m		0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		0	0
Barium	ppm	ASTM D5185m		0	0
Molybdenum	ppm	ASTM D5185m		<1	0
Manganese	ppm	ASTM D5185m		<1	0
Magnesium	ppm	ASTM D5185m		1	0
Calcium	ppm	ASTM D5185m		<1	1
Phosphorus	ppm	ASTM D5185m		3	4
Zinc	ppm	ASTM D5185m		0	0
Sulfur	ppm	ASTM D5185m		56	16

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>25	<1	<1
Sodium	ppm	ASTM D5185m		3	0
Potassium	ppm	ASTM D5185m	>20	1	<1
Water	%	ASTM D6304	>0.6	0.087	0.082
ppm Water	ppm	ASTM D6304	>6000	870.8	825.6

FLUID CLEANLINESS

method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647	>10000	6916	9589	1456
Particles >6µm	ASTM D7647	>2500	3080	3788	708
Particles >14µm	ASTM D7647	>320	529	603	173
Particles >21µm	ASTM D7647	>80	143	168	49
Particles >38µm	ASTM D7647	>20	4	4	4
Particles >71µm	ASTM D7647	>4	0	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/15	20/19/16	20/19/16	18/17/15


FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045		0.15	0.06




OIL ANALYSIS REPORT


▲ Particle Trend




Water (KF)




Acid Number



Water (KF)



Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	LIGHT	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.6	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	48.3	47.7	47.4

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USPM17939 **Received** : 25 Sep 2023
Lab Number : 05960693 **Diagnosed** : 26 Sep 2023
Unique Number : 10661906 **Diagnostician** : Doug Bogart
Test Package : IND 2

CARGILL FEED & NUTRITION - SALEM
 4186 STATE ROUTE 29
 SALEM, NY
 US 12865
 Contact: SEAN BERTRAND
 sean_bertrand@cargill.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)