




OIL ANALYSIS REPORT



Machine Id
Hancock CAT 3 (S/N 3RC00176)
 Component
Biogas Engine
 Fluid
CHEVRON HDAX LFG SAE 40 (--- GAL)

Sample Rating Trend



NORMAL



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0851193	WC0851183	WC0851191
Sample Date	Client Info		22 Sep 2023	08 Sep 2023	30 Aug 2023
Machine Age	hrs	Client Info	70203	69866	69650
Oil Age	hrs	Client Info	1221	884	668
Oil Changed	Client Info		Not Chngd	Not Chngd	Not Chngd
Sample Status			NORMAL	NORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>15	2	2
Chromium	ppm	ASTM D5185m	>4	<1	0
Nickel	ppm	ASTM D5185m	>2	1	0
Titanium	ppm	ASTM D5185m		0	0
Silver	ppm	ASTM D5185m	>5	0	0
Aluminum	ppm	ASTM D5185m	>6	3	<1
Lead	ppm	ASTM D5185m	>9	2	<1
Copper	ppm	ASTM D5185m	>14	<1	<1
Tin	ppm	ASTM D5185m	>4	5	4
Vanadium	ppm	ASTM D5185m		0	0
Cadmium	ppm	ASTM D5185m		0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0
Barium	ppm	ASTM D5185m		1	0
Molybdenum	ppm	ASTM D5185m		0	<1
Manganese	ppm	ASTM D5185m		<1	<1
Magnesium	ppm	ASTM D5185m		7	4
Calcium	ppm	ASTM D5185m		1993	2084
Phosphorus	ppm	ASTM D5185m	270	304	321
Zinc	ppm	ASTM D5185m	310	397	370
Sulfur	ppm	ASTM D5185m		2588	2576

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>181	147	141
Sodium	ppm	ASTM D5185m		0	1
Potassium	ppm	ASTM D5185m	>20	2	0

INFRA-RED




	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0.1	0.1
Nitration	Abs/cm	*ASTM D7624	>20	7.7	8.0
Sulfation	Abs.1mm	*ASTM D7415	>30	22.5	22.3

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs.1mm	*ASTM D7414	>25	19.6	19.2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.8	1.93	1.81
Base Number (BN)	mg KOH/g	ASTM D2896	6.0	3.76	3.75











OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	15.1	14.4	14.2

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : WC0851193 Received : 25 Sep 2023
 Lab Number : 05960754 Diagnosed : 27 Sep 2023
 Unique Number : 10661967 Diagnostician : Don Baldrige
 Test Package : MOB 2

EDL NA Recips-Hancock County
 HANCOCK COUNTY POWER STATION, 3574 TOWNSHIP ROAD 142
 FINDLAY, OH
 US 45840
 Contact: TIM CUSICK

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

tim.cusick@energydevelopments.com

T:

F: