




# OIL ANALYSIS REPORT

Sample Rating Trend



**DIRT**



Machine Id  
**Coopersville CAT 7 CPVM07BE**  
 Component  
**Biogas Engine**  
 Fluid  
**CHEVRON HDAX 6500 LFG GAS ENGINE OIL (--- GAL)**

## DIAGNOSIS

**Recommendation**  
 Oil and filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

**Wear**  
 All component wear rates are normal.

**Contamination**  
 Elemental level of silicon (Si) above normal.

**Fluid Condition**  
 The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0819463</b>	WC0819467	WC0819448
Sample Date	Client Info		<b>18 Sep 2023</b>	07 Sep 2023	22 Aug 2023
Machine Age	hrs	Client Info	<b>103248</b>	102985	102603
Oil Age	hrs	Client Info	<b>268</b>	1	634
Oil Changed	Client Info		<b>Changed</b>	Changed	Not Changed
Sample Status			<b>SEVERE</b>	ABNORMAL	SEVERE

## CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<b>&lt;1.0</b>	<1.0	<1.0
Glycol	WC Method		<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>15	<b>2</b>	3	3
Chromium	ppm	ASTM D5185m	>4	<b>&lt;1</b>	0	<1
Nickel	ppm	ASTM D5185m	>2	<b>1</b>	0	<1
Titanium	ppm	ASTM D5185m		<b>0</b>	0	0
Silver	ppm	ASTM D5185m	>5	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>6	<b>4</b>	<1	2
Lead	ppm	ASTM D5185m	>9	<b>4</b>	3	1
Copper	ppm	ASTM D5185m	>6	<b>2</b>	2	2
Tin	ppm	ASTM D5185m	>4	<b>8</b>	7	7
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		<b>2</b>	0	2
Barium	ppm	ASTM D5185m		<b>1</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>&lt;1</b>	2	4
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m		<b>12</b>	6	12
Calcium	ppm	ASTM D5185m		<b>1905</b>	2095	1804
Phosphorus	ppm	ASTM D5185m		<b>270</b>	300	262
Zinc	ppm	ASTM D5185m		<b>354</b>	359	335
Sulfur	ppm	ASTM D5185m		<b>2397</b>	2127	2445

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>181	<b>233</b>	197	209
Sodium	ppm	ASTM D5185m		<b>0</b>	1	0
Potassium	ppm	ASTM D5185m	>20	<b>2</b>	0	2

## INFRA-RED





	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844		<b>0.1</b>	0.1	0
Nitration	Abs/cm	*ASTM D7624	>20	<b>7.0</b>	9.0	6.2
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>20.7</b>	19.3	18.7

## FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>14.6</b>	16.0	11.9
Acid Number (AN)	mg KOH/g	ASTM D8045	1.2	<b>1.32</b>	1.52	0.95
Base Number (BN)	mg KOH/g	ASTM D2896	4.5	<b>4.16</b>	4.12	4.53











# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	14.7	13.9	14.1

## GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
 Sample No. : WC0819463 Received : 25 Sep 2023  
 Lab Number : 05960758 Diagnosed : 27 Sep 2023  
 Unique Number : 10661971 Diagnostician : Don Baldrige  
 Test Package : MOB 2

EDL NA Recips-Coopersville  
 Coopersville Powerstation, 15362 68th Avenue  
 Coopersville, MI  
 US 49404  
 Contact: Daniel Young  
 daniel.young@edlenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: