




# OIL ANALYSIS REPORT



Machine Id  
**COVM06BE (S/N GZJ00183)**  
 Component  
**Biogas Engine**  
 Fluid  
**CHEVRON HDAX 6500 LFG GAS ENGINE OIL (141 GAL)**

Sample Rating Trend



**NORMAL**



## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0816136</b>	WC0816138	WC0816134
Sample Date	Client Info		<b>21 Sep 2023</b>	15 Sep 2023	06 Sep 2023
Machine Age	hrs	Client Info	<b>127278</b>	127218	127093
Oil Age	hrs	Client Info	<b>433</b>	373	227
Oil Changed	Client Info		<b>Not Chngd</b>	Not Chngd	Filtered
Sample Status			<b>NORMAL</b>	NORMAL	NORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<b>&lt;1.0</b>	<1.0	<1.0
Glycol	WC Method		<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>15	<b>2</b>	2	2
Chromium	ppm	ASTM D5185m	>4	<b>&lt;1</b>	<1	<1
Nickel	ppm	ASTM D5185m	>2	<b>1</b>	0	<1
Titanium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Silver	ppm	ASTM D5185m	>5	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>6	<b>4</b>	2	4
Lead	ppm	ASTM D5185m	>9	<b>2</b>	1	2
Copper	ppm	ASTM D5185m	>6	<b>&lt;1</b>	<1	<1
Tin	ppm	ASTM D5185m	>4	<b>2</b>	1	1
Vanadium	ppm	ASTM D5185m		<b>0</b>	<1	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	<1	0

## ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		<b>6</b>	6	6
Barium	ppm	ASTM D5185m		<b>2</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>2</b>	4	5
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m		<b>32</b>	31	29
Calcium	ppm	ASTM D5185m		<b>1785</b>	1885	1765
Phosphorus	ppm	ASTM D5185m		<b>284</b>	294	277
Zinc	ppm	ASTM D5185m		<b>368</b>	356	353
Sulfur	ppm	ASTM D5185m		<b>2062</b>	2071	1972

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>181	<b>122</b>	112	99
Sodium	ppm	ASTM D5185m		<b>0</b>	0	0
Potassium	ppm	ASTM D5185m	>20	<b>1</b>	3	1

## INFRA-RED




	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844		<b>0</b>	0.1	0
Nitration	Abs/cm	*ASTM D7624	>20	<b>5.8</b>	5.6	6.0
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>17.1</b>	16.7	16.1

## FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>10.5</b>	10.0	9.5
Acid Number (AN)	mg KOH/g	ASTM D8045	1.2	<b>0.92</b>	0.67	1.66
Base Number (BN)	mg KOH/g	ASTM D2896	4.5	<b>4.97</b>	4.08	5.38











# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	14.7	13.6	13.5

## GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
 Sample No. : WC0816136 Received : 25 Sep 2023  
 Lab Number : 05960767 Diagnosed : 27 Sep 2023  
 Unique Number : 10661980 Diagnostician : Don Baldrige  
 Test Package : MOB 2

**EDL NA Recips-Covel**  
 COVEL GARDENS POWER STATION, 8611 COVEL ROAD  
 SAN ANTONIO, TX  
 US 78252  
 Contact: ARIEL CARRION  
 ariel.carrion@edlenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: