

PROBLEM SUMMARY

Sample Rating Trend

VISCOSITY

7415838 (S/N 1023)


Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY





RECOMMENDATION

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS											
Sample Status				ABNORMAL	ABNORMAL						
Particles >6µm		ASTM D7647	>1300	2708							
Particles >14µm		ASTM D7647	>80	▲ 365							
Particles >21µm		ASTM D7647	>20	120							
Particles >38µm		ASTM D7647	>4	<u> </u>							
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/19/16							
Visc @ 40°C	cSt	ASTM D445	45	57.69	44.3						

Customer Id: HERSAN Sample No.: KCP40082D Lab Number: 05961259 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS Action Status Date Done By Description Change Fluid -- -- ? Oil and filter change at the time of sampling has been noted. Change Filter -- ? Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

20 Apr 2021 Diag: Doug Bogart

VIS DEBRIS



Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



VISCOSITY

7415838 (S/N 1023)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

▲ Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

			Apr2021	Aug 2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		III III Dasc		_	•
Sample Number		Client Info		KCP40082D	KC83088	
Sample Date	laa	Client Info		30 Aug 2023	20 Apr 2021	
Machine Age	hrs	Client Info		23290	3940	
Oil Age	hrs	Client Info		3000 Ohammad	3940 Characad	
Oil Changed		Client Info		Changed	Changed ABNORMAL	
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	0	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	7	16	
Tin	ppm	ASTM D5185m	>10	0	<1	
Antimony	ppm	ASTM D5185m			<1	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	9	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m	100	0	0	
Calcium	ppm	ASTM D5185m	0	0	0	
Phosphorus	ppm	ASTM D5185m	0	<1	4	
Zinc	ppm	ASTM D5185m	0	0	0	
Sulfur	ppm	ASTM D5185m	23500	14664	14579	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon			>25	0	0	
Sodium	ppm	ASTM D5185m	>25	۰ <1	0	
Potassium	ppm	ASTM D5185m	- 20	0	<1	
Water	ppm %	ASTM D5165111	>20	0.005	0.006	
ppm Water	ppm	ASTM D6304	>0.05 >500	59.7	63.9	
FLUID CLEANLIN		method	limit/base	current	history1	history2
	LUU		IIIIIIVDase			HISTOTYZ
Particles >4µm		ASTM D7647	. 1200	7544 ^ 2708		
Particles >6µm						
Particles >14µm		ASTM D7647	>80	▲ 365 ▲ 100		
Particles >21µm		ASTM D7647	>20	<u>^</u> 120		
Particles >38µm		ASTM D7647	>4	<u>^</u> 7		
Particles >71µm		ASTM D7647		0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/19/16		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	ma K∩U/a	VGTM D804E	1.0	0.65	0.445	



OIL ANALYSIS REPORT







Sample No. Lab Number **Unique Number**

: KCP40082D : 05961259 : 10662472

Received Diagnosed

Diagnostician : Don Baldridge

: 29 Sep 2023

SANTA FE SPRINGS, CA

Contact: Service Manager

Test Package : IND 2 (Additional Tests: KF, PrtCount) Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

US 90670

T: F: