

OIL ANALYSIS REPORT

Sample Rating Trend



GARDNER DENVER GD-1 (R-155)

Component

Compressor

GARDNER DENVER AEON 9000 SP (--- GA

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

L)		Dec2019	Nov2020 Jul2021	Dec2021 Aug2022	Aug ² 023	
SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0001897	USP248088	USP242958
Sample Date		Client Info		24 Aug 2023	05 May 2023	21 Aug 2022
Machine Age	hrs	Client Info		42524	42241	41248
Oil Age	hrs	Client Info		3000	4500	4000
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
ron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Γitanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	0	<1
_ead	ppm	ASTM D5185m	>25	0	0	0
Copper	ppm	ASTM D5185m	>50	<1	0	8
Γin	ppm	ASTM D5185m	>15	<1	0	<1
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	0	0	0	0
Calcium	ppm	ASTM D5185m	0	0	0	16
Phosphorus	ppm	ASTM D5185m	800	641	667	62
Zinc	ppm	ASTM D5185m	0	0	0	11
Sulfur	ppm	ASTM D5185m	0	9	0	36
CONTAMINANTS	S	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	0	<1	<1
Nater	%	ASTM D6304	>0.1	0.037	0.031	△ 0.147
opm Water	ppm	ASTM D6304	>1000	377.9	310.2	▲ 1470.8
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	3733	2120	▲ 62862
Particles >6µm		ASTM D7647	>2500	795	289	<u>▲</u> 16075
Particles >14µm		ASTM D7647	>320	39	11	<u> </u>
Particles >21µm		ASTM D7647	>80	14	2	<u>224</u>
Particles >38µm		ASTM D7647	>20	1	0	12
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	19/17/12	18/15/11	<u>\$\rightarrow\$ 23/21/17</u>
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	.170	0.56	0.556	0.39



OIL ANALYSIS REPORT



Certificate L2367

Unique Number

Test Package

: 10662480

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

: IND 2

Diagnostician

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

: Doug Bogart

US 65625

T: F:

Contact: DANIEL FERGUSON