


Component

PROBLEM SUMMARY


Sample Rating Trend



Vacuum Pump USPI VAC 100 (--- GAL)

BUSCH VP-10B

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS								
Sample Status			ABNORMAL	ABNORMAL	ATTENTION			
Particles >4µm	ASTM D7647	>5000	18003		▲ 8767			
Particles >6µm	ASTM D7647	>1300	3636		▲ 1349			
Particles >14µm	ASTM D7647	>160	236		11			
Particles >21µm	ASTM D7647	>40	5 9		1			
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<u>^</u> 21/19/15		<u>^</u> 20/18/11			

Customer Id: TYSAMAPRO Sample No.: USPM29753 Lab Number: 05961785 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter			?	We recommend you service the filters on this component.

HISTORICAL DIAGNOSIS

25 Jun 2023 Diag: Doug Bogart





We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. There is a moderate amount of visible silt present in the sample. Free water present. There is a moderate concentration of water present in the oil. The oil viscosity is lower than normal. Confirmed. The AN level is acceptable for this fluid.



13 Mar 2023 Diag: Doug Bogart

VISCOSITY



Resample at the next service interval to monitor. SAMPLED AT DRAIN USPI-OFFLINEAll component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The oil viscosity is lower than normal. This plus the additive levels indicates the addition of a different brand, or type of oil. Confirmed. The AN level is acceptable for this fluid.



16 Jan 2023 Diag: Doug Bogart

DIKT




We recommend you service the filters on this component. We recommend an early resample to monitor this condition. The iron level is abnormal. The aluminum level is abnormal. There is a high amount of particulates present in the oil. Elemental level of silicon (Si) above normal indicating ingress of seal material. An increase in the sulfur level is noted. The AN level is acceptable for this fluid.





OIL ANALYSIS REPORT

Sample Rating Trend





BUSCH VP-10B

Component Vacuum Pump

USPI VAC 100 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Aug2022 S	ep2022 Dec2022 Dec20	22 Jan2023 Mar2023 Jun2023	3 Sep 2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USPM29753	USPM27136	USPM27559
Sample Date		Client Info		23 Sep 2023	25 Jun 2023	13 Mar 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	0	11	7
Chromium	ppm	ASTM D5185m	>20	0	<1	0
Nickel	ppm	ASTM D5185m	>20	0	<1	0
Titanium	ppm	ASTM D5185m		<1	0	<1
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>20	4	2	<1
Lead	ppm	ASTM D5185m	>20	0	2	0
Copper	ppm	ASTM D5185m	>20	<1	7	2
Tin	ppm	ASTM D5185m	>20	<1	2	0
Vanadium	ppm	ASTM D5185m		<1	0	<1
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	1	0
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	<1
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	0	<1	<1	0
Calcium	ppm	ASTM D5185m	0	<1	0	0
Phosphorus	ppm	ASTM D5185m	1800	874	252	<u> </u>
Zinc	ppm	ASTM D5185m	0	0	0	4
Sulfur	ppm	ASTM D5185m	0	5	183	0
CONTAMINANTS)	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	2	8	4
Sodium	ppm	ASTM D5185m		0	1	12
Potassium	ppm	ASTM D5185m		2	3	2
Water	%	ASTM D6304	>.1	0.089	▲ 0.690	0.005
ppm Water	ppm	ASTM D6304	>1000	897.6	▲ 6900	52.8
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	<u> </u>		▲ 8767
Particles >6µm		ASTM D7647	>1300	△ 3636		<u></u> 1349
Particles >14μm		ASTM D7647	>160	236		11
Particles >21µm		ASTM D7647	>40	<u>^</u> 59		1
Particles >38μm		ASTM D7647	>10	3		0
Particles >71µm		ASTM D7647	>3	1		0
Oil Cleanliness		ISO 4406 (c)	>19/17/14	<u>21/19/15</u>		<u>^</u> 20/18/11
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.05	0.06	0.46	0.51



OIL ANALYSIS REPORT



Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: