

### **PROBLEM SUMMARY**

### Sample Rating Trend


### **VISCOSITY**


# BUSCH VP-6B (S/N 0123)

**Vacuum Pump** 

**USPI VAC 100 (--- GAL)** 

### **COMPONENT CONDITION SUMMARY**





### RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS										
Sample Status				ATTENTION	ABNORMAL	MARGINAL				
Phosphorus	ppm	ASTM D5185m	1800	<b>△</b> 687	704	709				
Sulfur	ppm	ASTM D5185m	0	<u> </u>	0	0				
Visc @ 40°C	cSt	ASTM D445	91	<b>A</b> 80.0	109	97.5				

**Customer Id: TYSAMAPRO** Sample No.: USPM29756 Lab Number: 05961804 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

### HISTORICAL DIAGNOSIS

### 25 Jun 2023 Diag: Doug Bogart

ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 13 Mar 2023 Diag: Doug Bogart

WATER



Resample at the next service interval to monitor. All component wear rates are normal. There is a trace of moisture present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 14 Dec 2022 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





### **OIL ANALYSIS REPORT**

### Sample Rating Trend

### VISCOSITY


Machine Id

## BUSCH VP-6B (S/N 0123)

Component

Vacuum Pump

**USPI VAC 100 (--- GAL)** 





### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Woor

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

#### ▲ Fluid Condition

The oil viscosity is lower than normal. This plus the additive levels indicates the addition of a different brand or type of oil. Confirmed. The AN level is acceptable for this fluid.

		Jun 2022	Aug2022 Dec2023	2 Mar2023 Jun2023	Sep 2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USPM29756	USPM27158	USPM27581
Sample Date		Client Info		23 Sep 2023	25 Jun 2023	13 Mar 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ATTENTION	ABNORMAL	MARGINAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	<1	12	0
Chromium	ppm	ASTM D5185m	>20	0	<1	0
Nickel	ppm	ASTM D5185m	>20	0	<1	0
Titanium	ppm	ASTM D5185m		<1	0	<1
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>20	3	<1	0
Lead	ppm	ASTM D5185m	>20	0	0	0
Copper	ppm	ASTM D5185m	>20	2	0	0
Tin	ppm	ASTM D5185m	>20	<1	0	<1
Vanadium	ppm	ASTM D5185m		<1	0	<1
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	<1
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	0	<1	0	0
Calcium	ppm	ASTM D5185m	0	1	0	<1
Phosphorus	ppm	ASTM D5185m	1800	<b>△</b> 687	704	709
Zinc	ppm	ASTM D5185m	0	0	0	4
Sulfur	ppm	ASTM D5185m	0	<u>^</u> 219	0	0
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	7	4	5
Sodium	ppm	ASTM D5185m		<1	0	0
Potassium	ppm	ASTM D5185m	>20	2	0	<1
Water	%	ASTM D6304	>.1	0.073	0.075	<b>△</b> 0.108
ppm Water	ppm	ASTM D6304	>1000	734.3	750.5	<b>△</b> 1089.5
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647	>5000	3085	<u>▲</u> 111181	4157
Particles >6µm		ASTM D7647	>1300	790	<u>△</u> 23650	603
Particles >14μm		ASTM D7647	>160	66	<b>△</b> 609	15
Particles >21µm		ASTM D7647	>40	21	<u>▲</u> 57	1
Particles >38µm		ASTM D7647	>10	2	0	1
Particles >71μm		ASTM D7647	>3	1	0	0
Oil Cleanliness		ISO 4406 (c)	>19/17/14	19/17/13	<u>4</u> 24/22/16	19/16/11
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.05	0.085	0.19	0.14



### **OIL ANALYSIS REPORT**

