




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Area
[W116499]
 Machine Id
GENERAC RALEIGH 222 UNIT A
 Component
Diesel Engine
 Fluid
DIESEL ENGINE OIL SAE 15W40 (6 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

Metal levels are typical for a new component breaking in.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2	
Sample Number	Client Info	WC0753128	WC0682954	WCM1369588	
Sample Date	Client Info	13 Sep 2023	14 Sep 2022	07 Nov 2017	
Machine Age	hrs	Client Info	510	0	382
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info	N/A	N/A	Not Changd	
Sample Status		NORMAL	NORMAL	NORMAL	

CONTAMINATION

method	limit/base	current	history1	history2
Fuel	WC Method >5	<1.0	<1.0	<1.0
Glycol	WC Method	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >100	<1	2	2
Chromium	ppm	ASTM D5185m >20	0	0	0
Nickel	ppm	ASTM D5185m >4	0	0	0
Titanium	ppm	ASTM D5185m	6	<1	<1
Silver	ppm	ASTM D5185m >3	0	0	0
Aluminum	ppm	ASTM D5185m >20	3	2	<1
Lead	ppm	ASTM D5185m >40	1	1	3
Copper	ppm	ASTM D5185m >330	1	2	3
Tin	ppm	ASTM D5185m >15	<1	<1	0
Antimony	ppm	ASTM D5185m	---	---	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	<1

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 250	92	83	25
Barium	ppm	ASTM D5185m 10	0	1	0
Molybdenum	ppm	ASTM D5185m 100	83	57	3
Manganese	ppm	ASTM D5185m	0	<1	<1
Magnesium	ppm	ASTM D5185m 450	80	283	206
Calcium	ppm	ASTM D5185m 3000	2120	1863	2347
Phosphorus	ppm	ASTM D5185m 1150	1101	1075	906
Zinc	ppm	ASTM D5185m 1350	1290	1195	1109
Sulfur	ppm	ASTM D5185m 4250	4246	4503	3657

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >25	3	3	3
Sodium	ppm	ASTM D5185m >158	<1	0	4
Potassium	ppm	ASTM D5185m >20	1	2	2

INFRA-RED



method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844 >3	0.1	0.1	0
Nitration	Abs/cm	*ASTM D7624 >20	7.3	7.6	6.
Sulfation	Abs/.1mm	*ASTM D7415 >30	17.2	19.2	17.

FLUID DEGRADATION

method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414 >25	13.0	14.4	13.
Base Number (BN)	mg KOH/g	ASTM D2896 8.5	8.1	9.6	---











OIL ANALYSIS REPORT



PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	14.4	14.4	13.5

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0753128 **Received** : 27 Sep 2023
Lab Number : 05961955 **Diagnosed** : 28 Sep 2023
Unique Number : 10668506 **Diagnostician** : Wes Davis
Test Package : MOB 1 (Additional Tests: TBN)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

NATIONAL POWER CORP
 4541 PRESLYN DR
 RALEIGH, NC
 US 27616

Contact: ANDREW RANDALL
 andrew.randall@natpow.com

T: (919)790-1672

F: (919)790-9714