




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Area
[W116501]
 Machine Id
GENERAC RALEIGH MARSH MAINT
 Component
Diesel Engine
 Fluid
SHELL ROTELLA T 15W40 (7 GAL)



DIAGNOSIS

Recommendation
 Resample at the next service interval to monitor.

Wear
 Metal levels are typical for a new component breaking in.

Contamination
 There is no indication of any contamination in the oil.

Fluid Condition
 The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0812707	WC0812712	WC0770486
Sample Date	Client Info		12 Sep 2023	06 Jun 2023	16 Mar 2023
Machine Age	hrs	Client Info	199	394	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	Not Changd	Changed
Sample Status			NORMAL	NORMAL	ABNORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>2.1	<1.0	0.3	▲ 6.4
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>51	2	2
Chromium	ppm	ASTM D5185m	>11	0	<1
Nickel	ppm	ASTM D5185m	>5	0	0
Titanium	ppm	ASTM D5185m		28	25
Silver	ppm	ASTM D5185m	>3	0	0
Aluminum	ppm	ASTM D5185m	>31	3	<1
Lead	ppm	ASTM D5185m	>26	<1	<1
Copper	ppm	ASTM D5185m	>26	0	0
Tin	ppm	ASTM D5185m	>4	<1	<1
Vanadium	ppm	ASTM D5185m		<1	<1
Cadmium	ppm	ASTM D5185m		0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	316	115	117
Barium	ppm	ASTM D5185m	0.0	0	0
Molybdenum	ppm	ASTM D5185m	1.2	55	53
Manganese	ppm	ASTM D5185m		0	<1
Magnesium	ppm	ASTM D5185m	24	225	244
Calcium	ppm	ASTM D5185m	2292	1968	2097
Phosphorus	ppm	ASTM D5185m	1064	1059	1059
Zinc	ppm	ASTM D5185m	1160	1259	1271
Sulfur	ppm	ASTM D5185m	4996	4223	4785

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>22	6	7
Sodium	ppm	ASTM D5185m	>31	1	2
Potassium	ppm	ASTM D5185m	>20	2	1

INFRA-RED



	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	>3	0	0.1
Nitration	Abs/cm	*ASTM D7624	>20	6.7	7.2
Sulfation	Abs/.1mm	*ASTM D7415	>30	17.6	17.9

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	13.5	12.8
Base Number (BN)	mg KOH/g	ASTM D2896	10.1	8.3	8.8











OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.21	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	15.7	14.6	14.7 ▲ 11.8

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0812707 **Received** : 27 Sep 2023
Lab Number : 05961957 **Diagnosed** : 28 Sep 2023
Unique Number : 10668508 **Diagnostician** : Wes Davis
Test Package : MOB 1 (Additional Tests: TBN)

NATIONAL POWER CORP
 4541 PRESLYN DR
 RALEIGH, NC
 US 27616
 Contact: BRANDON RICE
 brandon.rice@natpow.com
 T:
 F: (919)790-9714

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)