




# OIL ANALYSIS REPORT

Sample Rating Trend

**NORMAL**



Area  
**[W116489]**  
 Machine Id  
**GENERAC RALEIGH BURWELL 600**  
 Component  
**Diesel Engine**  
 Fluid  
**DIESEL ENGINE OIL SAE 15W40 (12 GAL)**



## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

Metal levels are typical for a new component breaking in.

### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0812702</b>	WC0812708	WC0770485
Sample Date	Client Info		<b>11 Sep 2023</b>	09 Jun 2023	14 Mar 2023
Machine Age	hrs	Client Info	<b>214</b>	221	208
Oil Age	hrs	Client Info	<b>0</b>	221	0
Oil Changed	Client Info		<b>N/A</b>	Not Changd	N/A
Sample Status			<b>NORMAL</b>	NORMAL	NORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>5	<b>&lt;1.0</b>	<1.0	<1.0
Glycol	WC Method		<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>250	<b>1</b>	19	2
Chromium	ppm	ASTM D5185m	>10	<b>0</b>	<1	<1
Nickel	ppm	ASTM D5185m	>5	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m		<b>5</b>	<1	<1
Silver	ppm	ASTM D5185m	>3	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>35	<b>3</b>	<1	2
Lead	ppm	ASTM D5185m	>100	<b>&lt;1</b>	<1	<1
Copper	ppm	ASTM D5185m	>60	<b>&lt;1</b>	<1	<1
Tin	ppm	ASTM D5185m	>5	<b>&lt;1</b>	<1	0
Vanadium	ppm	ASTM D5185m		<b>0</b>	<1	<1
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	250	<b>109</b>	7	88
Barium	ppm	ASTM D5185m	10	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	100	<b>50</b>	65	43
Manganese	ppm	ASTM D5185m		<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185m	450	<b>353</b>	1022	348
Calcium	ppm	ASTM D5185m	3000	<b>1785</b>	1252	1877
Phosphorus	ppm	ASTM D5185m	1150	<b>992</b>	1116	1051
Zinc	ppm	ASTM D5185m	1350	<b>1189</b>	1398	1255
Sulfur	ppm	ASTM D5185m	4250	<b>4007</b>	4011	4747

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>35	<b>5</b>	4	5
Sodium	ppm	ASTM D5185m	>158	<b>1</b>	4	2
Potassium	ppm	ASTM D5185m	>20	<b>2</b>	<1	2

## INFRA-RED



	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844	>3	<b>0</b>	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	>20	<b>6.9</b>	5.6	7.1
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>17.3</b>	16.9	17.8

## FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>12.9</b>	12.1	12.3
Base Number (BN)	mg KOH/g	ASTM D2896	8.5	<b>8.1</b>	7.4	8.9











# OIL ANALYSIS REPORT



PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	14.4	13.0	12.9

### GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0812702 **Received** : 27 Sep 2023  
**Lab Number** : 05961971 **Diagnosed** : 28 Sep 2023  
**Unique Number** : 10668522 **Diagnostician** : Wes Davis  
**Test Package** : MOB 1 ( Additional Tests: TBN )

**NATIONAL POWER CORP**  
 4541 PRESLYN DR  
 RALEIGH, NC  
 US 27616  
 Contact: ANDREW RANDALL  
 andrew.randall@natpow.com  
 T: (919)790-1672  
 F: (919)790-9714

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)