



# OIL ANALYSIS REPORT


Sample Rating Trend

**NORMAL**



## Machine Id **VILTER ARTIC COLD STORAGE C3**

Component  
**Refrigeration Compressor**  
Fluid  
**NOT GIVEN (--- GAL)**



### DIAGNOSIS

- Recommendation**  
Resample at the next service interval to monitor.
- Wear**  
All component wear rates are normal.
- Contamination**  
There is no indication of any contamination in the oil.
- Fluid Condition**  
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0854641</b>	WC0688826	---
Sample Date	Client Info		<b>21 Sep 2023</b>	26 Aug 2022	---
Machine Age	hrs	Client Info	<b>168856</b>	0	---
Oil Age	hrs	Client Info	<b>0</b>	0	---
Oil Changed	Client Info		<b>N/A</b>	N/A	---
Sample Status			<b>NORMAL</b>	NORMAL	---

### WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >8	<b>4</b>	4	---
Chromium	ppm	ASTM D5185m >2	<b>0</b>	0	---
Nickel	ppm	ASTM D5185m	<b>0</b>	0	---
Titanium	ppm	ASTM D5185m	<b>0</b>	0	---
Silver	ppm	ASTM D5185m >2	<b>0</b>	0	---
Aluminum	ppm	ASTM D5185m >3	<b>&lt;1</b>	<1	---
Lead	ppm	ASTM D5185m >2	<b>0</b>	0	---
Copper	ppm	ASTM D5185m >8	<b>&lt;1</b>	<1	---
Tin	ppm	ASTM D5185m >4	<b>0</b>	<1	---
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	---
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	---

### ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	---
Barium	ppm	ASTM D5185m	<b>0</b>	0	---
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	---
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	---
Magnesium	ppm	ASTM D5185m	<b>0</b>	<1	---
Calcium	ppm	ASTM D5185m	<b>26</b>	14	---
Phosphorus	ppm	ASTM D5185m	<b>0</b>	<1	---
Zinc	ppm	ASTM D5185m	<b>0</b>	3	---
Sulfur	ppm	ASTM D5185m	<b>41</b>	48	---

### CONTAMINANTS




	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<b>&lt;1</b>	<1	---
Sodium	ppm	ASTM D5185m	<b>2</b>	0	---
Potassium	ppm	ASTM D5185m >20	<b>0</b>	<1	---
Water	%	ASTM D6304 >0.01	<b>0.001</b>	0.004	---
ppm Water	ppm	ASTM D6304 >100	<b>14.8</b>	46.2	---

### FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	<b>0.322</b>	0.014	---




# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	<b>LIGHT</b>	NONE	---
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	---
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE	---
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	---
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	---
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	---
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	---
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	---
Emulsified Water	scalar	*Visual	>0.01	<b>NEG</b>	NEG	---
Free Water	scalar	*Visual		<b>NEG</b>	NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	<b>75.6</b>	70.5	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0854641 **Received** : 27 Sep 2023  
**Lab Number** : **05962255** **Diagnosed** : 28 Sep 2023  
**Unique Number** : 10668806 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**D&H REFRIGERATION**  
 15811 ANNICO DRIVE UNITS 2&3  
 HOMER GLEN, IL  
 US 60491  
 Contact: JOE HANKINS  
 jhankins@dandhrefrigeration.com  
 T: (708)205-5693  
 F: x: