




# OIL ANALYSIS REPORT

Sample Rating Trend



**DEGRADATION**



Machine Id  
**WVTM02BE**  
Component  
**Biogas Engine**  
Fluid  
**CHEVRON HDAX 6500 LFG GAS ENGINE OIL (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil.

### ▲ Fluid Condition

The BN level is low. The AN level is at the top-end of the recommended limit.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0629357</b>	WC0629354	WC0629353
Sample Date	Client Info		<b>26 Sep 2023</b>	14 Sep 2023	06 Sep 2023
Machine Age	hrs	Client Info	<b>40316</b>	40055	39874
Oil Age	hrs	Client Info	<b>442</b>	181	1038
Oil Changed	Client Info		<b>Not Chngd</b>	Not Chngd	Changed
Sample Status			<b>ABNORMAL</b>	NORMAL	ABNORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<b>&lt;1.0</b>	<1.0	<1.0
Glycol	WC Method		<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >15	<b>6</b>	2	8
Chromium	ppm	ASTM D5185m >4	<b>0</b>	0	<1
Nickel	ppm	ASTM D5185m >2	<b>0</b>	0	1
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m >5	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >6	<b>4</b>	3	4
Lead	ppm	ASTM D5185m >9	<b>5</b>	<1	6
Copper	ppm	ASTM D5185m >6	<b>&lt;1</b>	<1	2
Tin	ppm	ASTM D5185m >4	<b>5</b>	2	6
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	<1
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>1</b>	1	2
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m	<b>7</b>	8	8
Calcium	ppm	ASTM D5185m	<b>1860</b>	1757	1879
Phosphorus	ppm	ASTM D5185m	<b>278</b>	250	262
Zinc	ppm	ASTM D5185m	<b>326</b>	310	332
Sulfur	ppm	ASTM D5185m	<b>3703</b>	2912	3828

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >181	<b>166</b>	69	▲ 191
Sodium	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1
Potassium	ppm	ASTM D5185m >20	<b>0</b>	<1	1

## INFRA-RED




	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	<b>0</b>	0.1	0.1
Nitration	Abs/cm	*ASTM D7624 >20	<b>5.2</b>	5.2	5.3
Sulfation	Abs/.1mm	*ASTM D7415 >30	<b>26.4</b>	18.5	26.2

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	<b>14.3</b>	9.1	14.0
Acid Number (AN)	mg KOH/g	ASTM D8045 1.2	▲ <b>2.61</b>	1.01	1.96
Base Number (BN)	mg KOH/g	ASTM D2896 4.5	▲ <b>1.79</b>	3.59	▲ 1.43











# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 100°C	cSt	ASTM D445	14.7	13.6	13.3	13.8

### GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0629357 **Received** : 27 Sep 2023  
**Lab Number** : 05962373 **Diagnosed** : 28 Sep 2023  
**Unique Number** : 10668924 **Diagnostician** : Jonathan Hester  
**Test Package** : MOB 2

**EDL NA Recips-Watervliet**  
 Watervliet Powerstation, 3563 Hennessey Road  
 Watervliet, MI  
 US 49098  
 Contact: Scott Eastman  
 scott.eastman@edlenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)