


COOLANT REPORT



OKLAHOMA/102/EG - DOZER 36.24L [OKLAHOMA^102^EG - DOZER]

Component Radiator Coolant

CATERPILLAR ELC (--- GAL)





Recommendation

No corrective action is recommended at this time. The fluid is suitable for further service.

All metal levels are normal indicating no corrosion in the cooling system.

Contamination

There is no indication of any contamination in the coolant.


Fluid Condition

Carboxylate test failed. The glycol level is acceptable. The pH level of this fluid is within the acceptable limits.

UAL)				Sep2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0848979		
Sample Date		Client Info		15 Sep 2023		
Machine Age	hrs	Client Info		2630		
Oil Age	hrs	Client Info		2630		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
PHYSICAL TEST F	RESULTS	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		1.067		
pH	Scale 0-14	ASTM D1287		7.51		
Nitrites	ppm	AP-053:2009		748		
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		49.7		
Freezing Point	°F	ASTM D3321		-33		
Total Dissolved Solids				366.5		
Carboxylate				fail		
CORROSION INH	IBITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D6130	0	45		
Phosphorus	ppm	ASTM D6130	0	97		
Boron	ppm	ASTM D6130	0	2		
Molybdenum	ppm	ASTM D6130	950	1002		
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D6130		0		
Aluminum	ppm	ASTM D6130		0		
Copper	ppm	ASTM D6130		4		
Lead	ppm	ASTM D6130		0		
Tin	ppm	ASTM D6130		0		
Zinc	ppm	ASTM D6130		0		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Chlorine	ppm	ASTM D6130		15		
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D6130		5432		
Potassium	ppm	ASTM D6130		895		
SCALE POTENTI	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D6130		<1		
Magnesium	ppm	ASTM D6130		0		



COOLANT REPORT





GRAPHS		
Iron/Tin/Silver	Reserve Alkalinity	
T	14T:	
iron	12 Abnormal	
• • • • • • • • • • • • • • • • • • •	10	
	Reserve Alkalinity	
	ve Alk	
-		
	Abnormal	
1		
- 522	737	
Sep 15/23	Sep 15/23	
Copper/Aluminum/Lead	Freeze Point	
copper	10	
• • • • • • • • • • • • • • • • • • •	0	
	5	
-		
	d -20	
	-30	
<u> </u>	-35	
†	-40	
2/23	-45 L	
Sep 15/23	Sep 15/23	
pH	Nitrites	
	Abnomal	
Abnormal	2500	
	2000	
Abnormal	SS	
	<u>s</u> 1500	
	1000	
	500 - Abnormal	
	0	
Sep15/23 —	Sep15/23 +	
G.	10 10	





Certificate L2367

Laboratory Sample No. Lab Number Unique Number : 10669161

: WC0848979 : 05962610

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received Diagnosed

Diagnostician : Jonathan Hester

: 27 Sep 2023 : 03 Oct 2023

Test Package : COOL- (Additional Tests: COOL, ICP)

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

SHERWOOD CONSTRUCTION CO INC 3219 WEST MAY ST WICHITA, KS US 67213

Contact: SHAWN SOUTH shawn.south@sherwood.net

T: x: F: x: