


COOLANT REPORT

KANSAS/44/HY - MOBILE EQUIPMENT 54.26L [KANSAS^44^HY - MOBILE EQUIPMENT]

Component Coolant

CAT EXTENDED LIFE COOLANT (ELC) (--- GAL)





DIAGNOSIS
D
Recommendation

The fluid is suitable for further service.

Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

There is no indication of any contamination in the coolant.


Coolant Condition

The carboxylate level of this fluid is acceptable. The glycol level is acceptable. The pH level of this fluid is within the acceptable limits.

			ooptoti	Ospiono		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0769740	WC0622821	
Sample Date		Client Info		20 Sep 2023	14 Sep 2021	
Machine Age	hrs	Client Info		2153	997	
Oil Age	hrs	Client Info		1700	997	
Oil Changed		Client Info		N/A	Oil Added	
Sample Status				NORMAL	NORMAL	
PHYSICAL TEST F	RESULTS	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		1.069		
Н	Scale 0-14	ASTM D1287		7.56	8.47	
Nitrites	ppm	AP-053:2009		488	260	
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		51.0	50	
Freezing Point	°F	ASTM D3321		-38	-38	
Total Dissolved Solids				399.5	386.0	
Carboxylate				pass	pass	
CORROSION INH	IBITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D6130	0	25	33	
Phosphorus	ppm	ASTM D6130	0	0	6	
Boron	ppm	ASTM D6130	0	330	398	
Molybdenum	ppm	ASTM D6130	950	616	718	
CORROSION		method	limit/base	current	history1	history2
ron	ppm	ASTM D6130	>15	<1	4	
Aluminum	ppm	ASTM D6130	>10	2	4	
Copper	ppm	ASTM D6130	>10	1	<1	
_ead	ppm	ASTM D6130	>10	0	0	
Γin	ppm	ASTM D6130	>10	0	0	
Zinc	ppm	ASTM D6130		11	0	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Chlorine	ppm	ASTM D6130		7	13	
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D6130		5485	3253	
Potassium	ppm	ASTM D6130		383	155	
SCALE POTENTI	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D6130		4	2	
Magnesium	ppm	ASTM D6130		2	3	




COOLANT REPORT





Bottom	no Image
GRAPHS	
Iron/Tin/Silver	Reserve Alkalinity
Abnormal iron	Abnormal
12 -	10
10+	
8+	Reserve Alkalinity
6+	38 4 4
4	Abnormal
2	0
Sep 14/21	Sep 20/23
Copper/Aluminum/Lead	Freeze Point
g copper aluminum	0+
8 - ••••••••••••• ead	10
6	Q-10+
4	0-4-20 1
3 -	-30
2	40-
0	-50
Sep14/21	Sep.20.723
рН	Nitrites
14	3000 Abnormal
Abnormal	2500
10 +	2000
8 - Abnormal	: <u>#</u> 1500-
6+	i li
	1000 -





Certificate L2367

Laboratory Sample No. Lab Number

Unique Number : 10669167

: WC0769740 : 05962616

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : 27 Sep 2023 Received

Diagnosed : 03 Oct 2023 Diagnostician : Jonathan Hester

Test Package : COOL- (Additional Tests: COOL, ICP) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

SHERWOOD CONSTRUCTION CO INC

3219 WEST MAY ST WICHITA, KS US 67213 Contact: DOUG KING doug.king@sherwood.net T: (316)617-3161

Report Id: SHEWIC [WUSCAR] 05962616 (Generated: 10/03/2023 12:59:57) Rev: 1

Submitted By: BOBBY JONES

F: x: