


PROBLEM SUMMARY

Sample Rating Trend




VISCOSITY




Area
REACTOR 2
Machine Id
A2 AGITATOR (S/N 11540A)
Component
Gearbox
Fluid
ROYAL PURPLE SYNFILM GT220 (13 GAL)

COMPONENT CONDITION SUMMARY

▲ Viscosity @ 40°C



▲ Particle Trend



RECOMMENDATION

No corrective actions at this time. While the viscosity continues to be low, it is acceptable for the agitator type. Continue to sample at the standard interval.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	ABNORMAL
Particles >4µm	ASTM D7647	>20000	▲ 42826	▲ 28995	▲ 41213
Particles >6µm	ASTM D7647	>5000	▲ 5668	3210	4886
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 23/20/16	▲ 22/19/14	▲ 23/19/14
Visc @ 40°C	cSt	ASTM D445 220	▲ 174	▲ 172	▲ 175

Customer Id: HEXHOPAR
Sample No.: PLS0000745
Lab Number: 05962832
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Mike Johnson +1 (615)771-6030
mike.johnson@amrri.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

13 Jul 2023 Diag: Doug Bogart

VISCOSITY



No corrective actions at this time. While the viscosity continues to be low, it is acceptable for the agitator type. Continue to sample at the standard interval. The wear rate is low and steady. Particles concentration is slightly elevated above what is expected for new oil. Visc @ 40°C is substantially low, but is within the trend for multiple samples. Based on additive concentrations that should not be present, there is an appearance of mixture with other oil types, but this condition is steady over multiple sample events. Other fluid health parameters suggest the lubricant is safe for continued use.

[view report](#)



10 Jun 2023 Diag: Mike Johnson

VISCOSITY



Filter oil if possible using B6=75 filter media or better. Confirm oil specification. Oil Viscosity is low compared to specification on file. Wear particles are low and acceptable. Contamination is slightly elevated. Filtration can help extend machine life. Fluid Viscosity is lower than the provided specification. If you believe the specification to be in error, contact Mike.Johnson@amrri.com to discuss and change fluid references.

[view report](#)



09 Mar 2023 Diag: Mike Johnson

VISCOSITY




Filter oil if possible using B6=75 filter media or better. Confirm oil is 220 or 150 oil. No other action required at this time. Resample at next normal interval. Wear particles are low and steady. Contamination is elevated in the sample. Confirm sample port is optimally placed. Filtration can extend machine life. Fluid viscosity is significantly lower than the reference oil of an ISO 220 viscosity. Confirm oil type.

[view report](#)



OIL ANALYSIS REPORT

Sample Rating Trend



VISCOSITY



Area
REACTOR 2
Machine Id
A2 AGITATOR (S/N 11540A)
Component
Gearbox
Fluid
ROYAL PURPLE SYNFILM GT220 (13 GAL)

DIAGNOSIS

Recommendation

No corrective actions at this time. While the viscosity continues to be low, it is acceptable for the agitator type. Continue to sample at the standard interval.

Wear

The wear rate is low and steady.

Contamination

Particles concentration is slightly elevated above what is expected for new oil.

Fluid Condition

Visc @ 40°C is substantially low, but is within the trend for multiple samples. Based on additive concentrations that should not be present, there is an appearance of mixture with other oil types, but this condition is steady over multiple sample events. Other fluid health parameters suggest the lubricant is safe for continued use.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		PLS0000745	PLS0000731	PLS0000607
Sample Date	Client Info		12 Sep 2023	13 Jul 2023	10 Jun 2023
Machine Age	mths	Client Info	7	5	4
Oil Age	mths	Client Info	7	5	4
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184		16	14	19
Iron	ppm	ASTM D5185m >200	6	8	8
Chromium	ppm	ASTM D5185m >15	0	<1	0
Nickel	ppm	ASTM D5185m >15	0	0	<1
Titanium	ppm	ASTM D5185m	<1	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	0	2	0
Lead	ppm	ASTM D5185m >100	0	<1	<1
Copper	ppm	ASTM D5185m >200	1	2	1
Tin	ppm	ASTM D5185m >25	0	0	0
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0
Barium	ppm	ASTM D5185m	0	0	2
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m 90	57	77	64
Calcium	ppm	ASTM D5185m	8	12	11
Phosphorus	ppm	ASTM D5185m	39	48	36
Zinc	ppm	ASTM D5185m	0	18	13
Sulfur	ppm	ASTM D5185m	18600	24121	17221

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	5	7	6
Sodium	ppm	ASTM D5185m	3	4	2
Potassium	ppm	ASTM D5185m >20	<1	1	<1

INFRA-RED


	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0	0	0.1
Nitration	Abs/cm	*ASTM D7624	2.7	2.8	2.9
Sulfation	Abs/.1mm	*ASTM D7415	28.0	28.9	29.0

FLUID CLEANLINESS


	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	▲ 42826	▲ 28995	▲ 41213
Particles >6µm	ASTM D7647	>5000	▲ 5668	3210	4886
Particles >14µm	ASTM D7647	>640	411	118	142
Particles >21µm	ASTM D7647	>160	122	35	25
Particles >38µm	ASTM D7647	>40	6	5	1
Particles >71µm	ASTM D7647	>10	2	3	0
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 23/20/16	▲ 22/19/14	▲ 23/19/14

OIL ANALYSIS REPORT


Particle Trend




PQ




Particle Trend



Acid Number



PQ




FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	25.0	26.4	26.6
Acid Number (AN)	mg KOH/g	ASTM D8045	0.37	0.38	0.37

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	220	220	175

SAMPLE IMAGES




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PLS0000745 **Received** : 27 Sep 2023
Lab Number : **05962832** **Diagnosed** : 02 Oct 2023
Unique Number : 10669383 **Diagnostician** : Mike Johnson
Test Package : IND 2 (Additional Tests: FT-IR, PQ, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

HEXION - HOPE PLANT
 185 N INDUSTRIAL DR
 HOPE, AR
 US 71801

Contact: JOSEPH MURPHY
 joseph.murphy@hexion.com;mike.johnson@amrri.com

T: (870)722-7305
 F: (870)722-5678