


## **PROBLEM SUMMARY**

Sample Rating Trend




Machine Id **6919608 (S/N 1130)** 

Component

Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

## **COMPONENT CONDITION SUMMARY**



## **RECOMMENDATION**

The filter change at the time of sampling has been noted. We were unable to perform a particle count due to a high concentration of particles present in this sample. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS									
Sample Status				SEVERE	ABNORMAL	ABNORMAL			
Water	%	ASTM D6304	>0.05	<b>△</b> 0.306	0.010	0.023			
ppm Water	ppm	ASTM D6304	>500	<b>3060</b>	100.5	238.9			
Debris	scalar	*Visual	NONE	▲ MODER	NONE	NONE			
Appearance	scalar	*Visual	NORML	HAZY	NORML	NORML			
Free Water	scalar	*Visual		<b>1.0</b>	NEG	NEG			

Customer Id: EARATL Sample No.: KCPA000085 Lab Number: 05962892 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

## **RECOMMENDED ACTIONS**

Action	Status	Date	Done By	Description
Alert			?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

## HISTORICAL DIAGNOSIS

## 03 Feb 2023 Diag: Don Baldridge

ISO



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



## 09 Jun 2022 Diag: Jonathan Hester

WEAR



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. The aluminum level is abnormal. All other component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



## 18 Oct 2021 Diag: Jonathan Hester

WATER



We advise that you stop the unit and follow the water drain-off procedure for this component. The filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. There is a light concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





## **OIL ANALYSIS REPORT**

Sample Rating Trend





# 6919608 (S/N 1130)

Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

## DIAGNOSIS

## Recommendation

The filter change at the time of sampling has been noted. We were unable to perform a particle count due to a high concentration of particles present in this sample. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

All component wear rates are normal.

## Contamination

Appearance is hazy. Free water present. There is a moderate concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil.

## **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jul2020	Oct2021	Jun2022 Feb2023	Sep 2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA000085	KCP54782	KCP51143
Sample Date		Client Info		18 Sep 2023	03 Feb 2023	09 Jun 2022
Machine Age	hrs	Client Info		6229	5312	3715
Oil Age	hrs	Client Info		0	1596	2600
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				SEVERE	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	4	3	6
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	8	6	<u>15</u>
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	2	1	2
Tin	ppm	ASTM D5185m	>10	0	0	<1
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m		0	2	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		0	1	2
Calcium	ppm	ASTM D5185m		2	0	0
Phosphorus	ppm	ASTM D5185m	500	462	418	373
Zinc	ppm	ASTM D5185m		219	212	294
Sulfur	ppm	ASTM D5185m		1884	1665	2527
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	0
Sodium	ppm	ASTM D5185m		2	0	1
Potassium	ppm	ASTM D5185m	>20	<1	2	<1
Water	%	ASTM D6304	>0.05	<b>△</b> 0.306	0.010	0.023
ppm Water	ppm	ASTM D6304	>500	△ 3060	100.5	238.9
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			24164	984
Particles >6µm		ASTM D7647	>1300		<u>▲</u> 3242	386
Particles >14μm		ASTM D7647	>80		15	21
Particles >21μm		ASTM D7647	>20		4	4
Particles >38μm		ASTM D7647	>4		1	1
Particles >71μm		ASTM D7647	>3		0	1
Oil Cleanliness		ISO 4406 (c)	>/17/13		<u>22/19/11</u>	17/16/12

Acid Number (AN)


mg KOH/g ASTM D8045 1.5

1.18 0.91

0.80 Contact/Location: P. LOPEZ - EARATL



## **OIL ANALYSIS REPORT**







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** 

: 05962892 : 10669443

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KCPA000085 Received

Diagnosed

: 27 Sep 2023 : 29 Sep 2023

Diagnostician : Jonathan Hester

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**EARTH FRESH** 

3800 NATURALLY FRESH BLVD ATLANTA, GA

US 30349 Contact: P. LOPEZ

plopez@earthfreshfoods.com

T: F:

Contact/Location: P. LOPEZ - EARATL