

PROBLEM SUMMARY

Sample Rating Trend




7292517 (S/N 1598)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ATTENTION	NORMAL	ABNORMAL				
Particles >14µm	ASTM D7647	>80	<u></u> ▲ 88	56	<u>▲</u> 182				
Particles >21µm	ASTM D7647	>20	28	15	△ 63				
Oil Cleanliness	ISO 4406 (c)	>/17/13	19/17/14	19/17/13	2 0/18/15				

Customer Id: INSCUM Sample No.: KCPA002183 Lab Number: 05962899 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

24 Jan 2023 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



18 Jul 2022 Diag: Don Baldridge

ISO



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



29 Nov 2021 Diag: Angela Borella

NORMAL




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



7292517 (S/N 1598)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Mar2021	Nov2021	Jul2022 Jan2023	Sep2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA002183	KCP49200	KCP51667
Sample Date		Client Info		11 Sep 2023	24 Jan 2023	18 Jul 2022
Machine Age	hrs	Client Info		20583	15156	10591
Oil Age	hrs	Client Info		0	8566	4001
Oil Changed		Client Info		N/A	Changed	Not Changd
Sample Status				ATTENTION	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m		0	<1	<1
Lead	ppm	ASTM D5185m	>10	0	1	0
Copper	ppm		>50	5	7	2
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	20	41
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	90	43	53	70
Calcium	ppm	ASTM D5185m	2	<1	1	<1
Phosphorus	ppm	ASTM D5185m		3	0	1
Zinc	ppm	ASTM D5185m		0	10	2
Sulfur	ppm	ASTM D5185m		17814	19277	21158
CONTAMINANTS	5	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	2	0
Sodium	ppm	ASTM D5185m		13	16	18
Potassium	ppm		>20	3	5	2
Water	%	ASTM D6304		0.031	0.018	0.041
ppm Water	ppm	ASTM D6304	>500	319.7	184.4	416.3
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		4518	4781	8360
Particles >6µm		ASTM D7647		1136	1142	<u> </u>
Particles >14μm		ASTM D7647	>80	<u>^</u> 88	56	<u> 182</u>
Particles >21µm		ASTM D7647	>20	<u>^</u> 28	15	<u>^</u> 63
Particles >38µm		ASTM D7647	>4	3	2	<u> 5</u>
Particles >71μm		ASTM D7647	>3	2	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>	19/17/13	<u>^</u> 20/18/15
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2

0.30

0.29

0.36



OIL ANALYSIS REPORT

