



# **PROBLEM SUMMARY**



# Machine Id 6630034 (S/N 1213) Component

Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

# COMPONENT CONDITION SUMMARY



# RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status		ABNORMAL	ABNORMAL	ATTENTION			
Particles >6µm	ASTM D7647 >13	00 🔺 4053	<b>4</b> 9914	866			
Particles >14µm	ASTM D7647 >80	🔺 174	<b>1</b> 79	<b>1</b> 01			
Particles >21µm	ASTM D7647 >20	<b>4</b> 5	17	<u> </u>			
Oil Cleanliness	ISO 4406 (c) >/	17/13 🔺 <b>22/19/15</b>	🔺 22/20/15	🔺 17/14			

Customer Id: THONAP Sample No.: KC125779 Lab Number: 05962911 Test Package: IND 2



To manage this report scan the QR code

*To discuss the diagnosis or test data:* Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

# **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

# HISTORICAL DIAGNOSIS

# 24 Mar 2023 Diag: Jonathan Hester



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

### 13 Jan 2022 Diag: Don Baldridge

06 May 2021 Diag: Jonathan Hester



No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report



### VIS DEBRIS



The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

SAMPLE INFORMATION method

# Sample Rating Trend ISO

current

history1

historv2

Machine Id 6630034 (S/N 1213) Component

Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

# DIAGNOSIS

# Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

# Wear

All component wear rates are normal.

# Contamination

There is a high amount of particulates present in the oil.

## Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC125779	KC99694	KC89829
Sample Date		Client Info		12 Sep 2023	24 Mar 2023	13 Jan 2022
Machine Age	hrs	Client Info		6002	4905	2335
Oil Age	hrs	Client Info		0	3081	511
Oil Changed		Client Info		N/A	Changed	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	3	3	<1
Tin	ppm	ASTM D5185m	>10	0	0	<1
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	23
Barium	ppm	ASTM D5185m	90	0	0	12
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	90	68	67	82
Calcium	ppm	ASTM D5185m		1	<1	2
Phosphorus	ppm	ASTM D5185m		4	3	4
Zinc	ppm	ASTM D5185m		0	6	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	0
Sodium	ppm	ASTM D5185m		20	22	21
Potassium	ppm	ASTM D5185m	>20	1	2	3
Water	%	ASTM D6304	>0.05	0.022	0.023	0.022
ppm Water	ppm	ASTM D6304	>500	227.8	234.3	228.8
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		24724	27741	2663
Particles >6µm		ASTM D7647	>1300	<u> </u>	<b>9</b> 914	866
Particles >14µm		ASTM D7647	>80	<u> </u>	<b>1</b> 79	<b>1</b> 01
Particles >21µm		ASTM D7647	>20	<u> </u>	17	<u> </u>
Particles >38µm		ASTM D7647	>4	2	0	0
Particles >71µm		ASTM D7647	>3	1	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>A</b> 22/19/15	▲ 22/20/15	▲ 17/14
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.31	0.33	0.316


limit/base




# **OIL ANALYSIS REPORT**







VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.2	44.1	44.4
SAMPLE IMAGES	S	method	limit/base	current	history1	history2
Color						
Bottom						



Contact/Location: SERVICE MANAGER - THONAP