




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
8357128 (S/N 1791)

Component
Compressor

Fluid
KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	KC107604	KC110776	KC101059
Sample Date	Client Info	14 Sep 2023	05 Jun 2023	02 Mar 2023
Machine Age	hrs	3614	2463	1402
Oil Age	hrs	0	2463	1402
Oil Changed	Client Info	Changed	Not Changd	Not Changd
Sample Status		NORMAL	NORMAL	NORMAL

WEAR METALS

method	limit/base	current	history1	history2
Iron ppm	ASTM D5185m >50	0	<1	0
Chromium ppm	ASTM D5185m >10	0	0	0
Nickel ppm	ASTM D5185m >3	0	0	0
Titanium ppm	ASTM D5185m >3	<1	0	0
Silver ppm	ASTM D5185m >2	0	0	0
Aluminum ppm	ASTM D5185m >10	0	0	<1
Lead ppm	ASTM D5185m >10	0	<1	0
Copper ppm	ASTM D5185m >50	2	3	2
Tin ppm	ASTM D5185m >10	0	0	0
Vanadium ppm	ASTM D5185m	0	0	0
Cadmium ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron ppm	ASTM D5185m	0	0	0
Barium ppm	ASTM D5185m 90	22	21	38
Molybdenum ppm	ASTM D5185m	0	0	0
Manganese ppm	ASTM D5185m	<1	0	<1
Magnesium ppm	ASTM D5185m 90	76	71	74
Calcium ppm	ASTM D5185m 2	2	3	4
Phosphorus ppm	ASTM D5185m	12	2	1
Zinc ppm	ASTM D5185m	0	5	4

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm	ASTM D5185m >25	<1	0	3
Sodium ppm	ASTM D5185m	9	16	12
Potassium ppm	ASTM D5185m >20	4	16	10
Water %	ASTM D6304 >0.05	0.023	0.029	0.016
ppm Water	ASTM D6304 >500	234.7	293.1	168.7






FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	2537	1855	2180
Particles >6µm	ASTM D7647 >1300	656	356	544
Particles >14µm	ASTM D7647 >80	40	18	25
Particles >21µm	ASTM D7647 >20	11	5	6
Particles >38µm	ASTM D7647 >4	2	0	1
Particles >71µm	ASTM D7647 >3	0	0	0
Oil Cleanliness	ISO 4406 (c) >--/17/13	19/17/12	18/16/11	18/16/12

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g	ASTM D8045 0.4	0.33	0.30	0.31


OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 46	44.0	43.8	43.6

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KC107604 **Received** : 27 Sep 2023
Lab Number : 05962914 **Diagnosed** : 28 Sep 2023
Unique Number : 10669465 **Diagnostician** : Doug Bogart
Test Package : IND 2

STRATMAN
 28041 TRADE WAY DR - UNIT 1
 BONITA SPRINGS, FL
 US 34135
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: