

OIL ANALYSIS REPORT

Sample Rating Trend
ISO

Machine Id **2632** Component **Hydraulic System** Fluid **HVI 22 (--- QTS)**

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition. Please specify the component make and model with your next sample.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

				Sep2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		RW0004703		
Sample Date		Client Info		15 Sep 2023		
Machine Age	hrs	Client Info		2524		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	3		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>10	0		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>10	<1		
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm	ASTM D5185m	>75	3		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
			IIIIII/Dase			,
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		45		
Phosphorus	ppm	ASTM D5185m		339		
Zinc	ppm	ASTM D5185m		420		
Sulfur	ppm	ASTM D5185m		903		
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>20	3		
Sodium	ppm	ASTM D5185m		1		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	<u> </u>		
Particles >6µm		ASTM D7647	>1300	327		
Particles >14µm		ASTM D7647	>160	19		
Particles >21µm		ASTM D7647	>40	7		
Particles >38µm		ASTM D7647	>10	0		
Particles >71μm		ASTM D7647	>3	0		
·						
Oil Cleanliness		ISO 4406 (c)	>19/17/14	<u> </u>		
	NOITA	. ,				
Oil Cleanliness FLUID DEGRADA Acid Number (AN)	ATION mg KOH/g	ISO 4406 (c) method ASTM D8045	>19/17/14 limit/base	21/16/11 current 0.29	history1	history2



OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: RW0004703 : 05963520 : 10670071 Test Package : MOB 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 28 Sep 2023 : 29 Sep 2023 Diagnosed : Wes Davis Diagnostician

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

NEWKIRK ELECTRIC

1875 ROBERTS ST. MUSKEGON, MI US 49442

Contact: ERIC KING

ewking@newkirk-electric.com T: (231)206-6131

F: (231)724-4090

Contact/Location: ERIC KING - NEWMUS