

PROBLEM SUMMARY

Sample Rating Trend

ISO


AF12-250-M82374 COOLING WHEEL 2 TURNING MOTOR 1

Component

Gear Drive

MOBIL MOBILGEAR SHC 220 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

| PROBLEMATIC TEST RESULTS | | | | | | | | |
|--------------------------|--------------|-----------|-----------------|--|--|--|--|--|
| Sample Status | | | ATTENTION | | | | | |
| Particles >4µm | ASTM D7647 | >20000 | <u>^</u> 23033 | | | | | |
| Oil Cleanliness | ISO 4406 (c) | >21/19/16 | 22/19/13 | | | | | |

Customer Id: ARAGRAUS Sample No.: WC0848203 Lab Number: 05963543 Test Package: PLANT

To manage this report scan the QR code

To discuss the diagnosis or test data: Wes Davis +1 905-569-8600 x223 wesd@wearcheck.ca


To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

| RECOMMENDED ACTIONS | | | | | | | |
|----------------------|--------|------|---------|--|--|--|--|
| Action | Status | Date | Done By | Description | | | |
| Change Filter | | | ? | We recommend you service the filters on this component. | | | |
| Information Required | | | ? | NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. | | | |

HISTORICAL DIAGNOSIS



OIL ANALYSIS REPORT



AF12-250-M82374 COOLING WHEEL 2 TURNING MOTOR 1

Gear Drive

MOBIL MOBILGEAR SHC 220 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

There is a light amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| | | | | Sep2023 | | |
|-----------------------|------------|---------------|------------|-------------------|----------|----------|
| SAMPLE INFORM | MATION | method | limit/base | current | history1 | history2 |
| Sample Number | | Client Info | | WC0848203 | | |
| Sample Date | | Client Info | | 12 Sep 2023 | | |
| Machine Age | mths | Client Info | | 60 | | |
| Oil Age | mths | Client Info | | 12 | | |
| Oil Changed | 1111113 | Client Info | | Changed | | |
| Sample Status | | Ollerit IIIIO | | ATTENTION | | |
| WEAR METALS | | method | limit/base | current | history1 | history2 |
| PQ | | ASTM D8184 | | 15 | | |
| Iron | ppm | ASTM D5185m | >150 | 1 | | |
| Chromium | ppm | ASTM D5185m | >100 | 0 | | |
| Nickel | | ASTM D5185m | >10 | 0 | | |
| Titanium | ppm | ASTM D5185m | >10 | - | | |
| | ppm | | | 0 | | |
| Silver | ppm | ASTM D5185m | 0.5 | - | | |
| Aluminum | ppm | ASTM D5185m | >25 | <1 | | |
| Lead | ppm | ASTM D5185m | >100 | 0 | | |
| Copper | ppm | ASTM D5185m | >50 | <1 | | |
| Tin | ppm | ASTM D5185m | >10 | 0 | | |
| Vanadium | ppm | ASTM D5185m | | 0 | | |
| Cadmium | ppm | ASTM D5185m | | 0 | | |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | | <1 | | |
| Barium | ppm | ASTM D5185m | | 0 | | |
| Molybdenum | ppm | ASTM D5185m | | 0 | | |
| Manganese | ppm | ASTM D5185m | | <1 | | |
| Magnesium | ppm | ASTM D5185m | | 0 | | |
| Calcium | ppm | ASTM D5185m | | 0 | | |
| Phosphorus | ppm | ASTM D5185m | | 491 | | |
| Zinc | ppm | ASTM D5185m | | 0 | | |
| Sulfur | ppm | ASTM D5185m | | 4190 | | |
| CONTAMINANTS | 3 | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >50 | 16 | | |
| Sodium | ppm | ASTM D5185m | | <1 | | |
| Potassium | ppm | ASTM D5185m | >20 | 0 | | |
| Water | % | ASTM D6304 | >0.1 | 0.00 | | |
| ppm Water | ppm | ASTM D6304 | >1000 | 0.00 | | |
| FLUID CLEANLIN | IESS | method | limit/base | current | history1 | history2 |
| Particles >4μm | | ASTM D7647 | >20000 | 23033 | | |
| Particles >6µm | | ASTM D7647 | >5000 | 2736 | | |
| Particles >14µm | | ASTM D7647 | >640 | 79 | | |
| Particles >21µm | | ASTM D7647 | | 20 | | |
| Particles >38µm | | ASTM D7647 | >40 | 0 | | |
| Particles >71µm | | ASTM D7647 | | 0 | | |
| Oil Cleanliness | | ISO 4406 (c) | >21/19/16 | <u>^</u> 22/19/13 | | |
| FLUID DEGRADA | ATION | method | limit/base | current | history1 | history2 |
| Acid Number (AN) | mg KOH/g | ASTM D8045 | | 0.84 | | |
| , wid radilibel (AIA) | my NOI I/y | 70 LINI D0040 | | U.U T | | |



OIL ANALYSIS REPORT





Certificate L2367

Sample No. Lab Number **Unique Number** Test Package

: WC0848203 : 05963543

: 10670094

: PLANT

Received Diagnosed Diagnostician

: 28 Sep 2023 : 29 Sep 2023 : Wes Davis

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) 5851 ARAUCO ROAD GRAYLING, MI

US 49738 Contact: JOSEPH GREEN

joseph.green@arauco.com

T: F: