




# PROBLEM SUMMARY


Sample Rating Trend



Machine Id  
**KAESER SM20 4690436 (S/N 3339)**  
 Component  
**Compressor**  
 Fluid  
**KAESER SIGMA (OEM) S-460 (--- GAL)**

## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	ABNORMAL
Particles >6µm	ASTM D7647	>1300	▲ 43832	---	▲ 1396
Particles >14µm	ASTM D7647	>80	▲ 3176	---	▲ 237
Particles >21µm	ASTM D7647	>20	▲ 582	---	▲ 80
Particles >38µm	ASTM D7647	>4	▲ 10	---	▲ 12
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ 24/23/19	---	▲ 18/15

Customer Id: WESBER  
 Sample No.: KC05963591  
 Lab Number: 05963591  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

*There are no recommended actions for this sample.*

## HISTORICAL DIAGNOSIS

### 17 Apr 2023 Diag: Don Baldrige

#### VIS DEBRIS



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 18 Oct 2017 Diag: Don Baldrige

#### WATER



We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend you service the filters on this component. We recommend an early resample in 500 hours to monitor this condition. All component wear rates are normal. There is a high amount of particulates present in the oil. Free water present. The AN level is acceptable for this fluid.

view report



### 04 Apr 2017 Diag: Jonathan Hester


#### ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The oil is no longer serviceable due to the presence of contaminants.

view report





Machine Id  
**KAESER SM20 4690436 (S/N 3339)**

Component  
**Compressor**  
Fluid  
**KAESER SIGMA (OEM) S-460 (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### ▲ Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>KC05963591</b>	KC101633	KC64101
Sample Date	Client Info		<b>22 Sep 2023</b>	17 Apr 2023	18 Oct 2017
Machine Age	hrs	Client Info	<b>47684</b>	46485	21872
Oil Age	hrs	Client Info	<b>0</b>	0	2331
Oil Changed	Client Info		<b>N/A</b>	Not Changd	Not Changd
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>2</b>	0	1
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >3	<b>0</b>	0	1
Titanium	ppm	ASTM D5185m >3	<b>&lt;1</b>	0	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >10	<b>&lt;1</b>	<1	1
Lead	ppm	ASTM D5185m >10	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >50	<b>5</b>	<1	10
Tin	ppm	ASTM D5185m >10	<b>0</b>	0	2
Antimony	ppm	ASTM D5185m	<b>---</b>	---	2
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	<1
Barium	ppm	ASTM D5185m 90	<b>0</b>	6	2
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	<1
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m 90	<b>39</b>	80	17
Calcium	ppm	ASTM D5185m 2	<b>0</b>	0	2
Phosphorus	ppm	ASTM D5185m	<b>0</b>	<1	2
Zinc	ppm	ASTM D5185m	<b>8</b>	0	10

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<b>2</b>	<1	2
Sodium	ppm	ASTM D5185m	<b>11</b>	16	3
Potassium	ppm	ASTM D5185m >20	<b>&lt;1</b>	0	<1
Water	%	ASTM D6304 >0.05	<b>0.022</b>	0.020	0.028
ppm Water	ppm	ASTM D6304 >500	<b>220.7</b>	207.8	280






## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>109293</b>	---	2564
Particles >6µm	ASTM D7647	>1300	<b>▲ 43832</b>	---	▲ 1396
Particles >14µm	ASTM D7647	>80	<b>▲ 3176</b>	---	▲ 237
Particles >21µm	ASTM D7647	>20	<b>▲ 582</b>	---	▲ 80
Particles >38µm	ASTM D7647	>4	<b>▲ 10</b>	---	▲ 12
Particles >71µm	ASTM D7647	>3	<b>1</b>	---	1
Oil Cleanliness	ISO 4406 (c)	>--/17/13	<b>▲ 24/23/19</b>	---	▲ 18/15

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.4	<b>0.35</b>	0.38	0.319


# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	HAZY
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	0.1%
Free Water	scalar	*Visual	NEG	NEG	2.0

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 46	44.8	43.9	43.92

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KC05963591  
**Lab Number** : 05963591  
**Unique Number** : 10670142  
**Test Package** : IND 2

**WESTERN INTERNATIONAL GAS**  
 53 RIVER RD  
 BERWICK, PA  
 US 18603  
 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)