

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



NER Machine Id MYCOM NH3 - NER-BOOSTER 4 OK20080 (S/N MK6B/WRV1321132)

Refrigeration Compressor

JAX CRYOGUARD PLUS 68 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Dec2012	NOVZU13 JUIZUZ1	Jan2022 Mar2023 Jul2023	Sep2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP242791	USP240459	USP242790
Sample Date		Client Info		27 Sep 2023	04 Jul 2023	16 Mar 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	ATTENTION	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	0	0	3
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		0	<1	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	<1	<1	0
Lead	ppm	ASTM D5185m	>2	0	0	0
Copper	ppm	ASTM D5185m	>8	<1	0	0
Tin	ppm	ASTM D5185m	>4	0	<1	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m		0	0	<1
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		0	0	0
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m		24	11	2
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	<1	2
Sodium	ppm	ASTM D5185m		<1	0	<1
Potassium	ppm	ASTM D5185m	>20	0	1	0
Water	%	ASTM D6304	>0.01	0.001	0.001	0.004
ppm Water	ppm	ASTM D6304	>100	4.1	0.00	41.2
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	725	1 9610	▲ 38051
Particles >6µm		ASTM D7647	>2500	201	▲ 2884	<u>▲</u> 4197
Particles >14μm		ASTM D7647	>320	17	25	103
Particles >21µm		ASTM D7647	>80	4	4	13
Particles >38μm		ASTM D7647	>20	0	0	1
Particles >71μm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	17/15/11	<u>\$\text{\Delta}\$ 21/19/12</u>	<u>22/19/14</u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

Acid Number (AN) mg

mg KOH/g ASTM D974

0.015 0.015 0.014

Report Id: SCHSTI [WUSCAR] 05963612 (Generated: 09/29/2023 09:28:06) Rev: 1

Contact/Location: DENNIS LONGSHORE - SCHSTI



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number**

: USP242791 : 05963612

: 10670163 Test Package : IND 2

: 28 Sep 2023 Received Diagnosed : 29 Sep 2023 Diagnostician

: Doug Bogart

5 EAST WALNUT STILWELL, OK

US 74960

Contact: DENNIS LONGSHORE

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) T: (918)696-8296 F: