

## **OIL ANALYSIS REPORT**

## **NORMAL**



# VILTER NH3 - WH5-VILTER 3 OK21050 (S/N 61093)

**Refrigeration Compressor** 

**JAX CRYOGUARD PLUS 68 (6 GAL)** 

# DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

## **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				_		
Dec2012	Nov2013	Jul2021	Jan 2022	Jan 2023	Jul2023	Sep202

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP242826	USP242827	USP240473
Sample Date		Client Info		27 Sep 2023	04 Jul 2023	19 Jan 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	0	0	6
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	<1	<1	0
Lead	ppm	ASTM D5185m	>2	0	0	0
Copper	ppm	ASTM D5185m	>8	<1	0	0
Tin	ppm	ASTM D5185m	>4	0	0	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		0	0	0
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m		0	19	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	0	<1
Sodium	ppm	ASTM D5185m		<1	0	0
Potassium	ppm	ASTM D5185m	>20	0	1	0
Water	%	ASTM D6304	>0.01	0.001	0.001	△ 0.061
ppm Water	ppm	ASTM D6304	>100	0.00	0.00	<b>△</b> 610
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	1629	3071	<b>△</b> 353673
Particles >6µm		ASTM D7647	>2500	392	697	<b>△</b> 94498
Particles >14μm		ASTM D7647	>320	11	22	252
Particles >21µm		ASTM D7647	>80	2	5	18
Particles >38µm		ASTM D7647	>20	0	0	0
Particles >71μm		ASTM D7647		0	0	0

FLUID DEGRADATION

Oil Cleanliness

ISO 4406 (c) >20/18/15

19/17/12

18/16/11

**26/24/15** 



## **OIL ANALYSIS REPORT**







Certificate L2367

Sample No. Lab Number **Unique Number** Test Package

: USP242826 : 05963618

: 10670169 : IND 2

: 28 Sep 2023 Received : 29 Sep 2023 Diagnosed

Diagnostician : Doug Bogart **5 EAST WALNUT** 

STILWELL, OK US 74960

Contact: DENNIS LONGSHORE

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (918)696-8296 F: