

PROBLEM SUMMARY

Sample Rating Trend






RAL-CFU112A

Component Gearbox

SUMMIT SYNGEAR PG 460 (--- QTS)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check for the source of water entry. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS									
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL			
Water	%	ASTM D6304	>0.2	△ 0.921	△ 0.246	△ 0.249			
ppm Water	ppm	ASTM D6304	>2000	9210	2465.2	2 496.3			

Customer Id: HOLCOR Sample No.: RP0033589 Lab Number: 05963648 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Resample			?	We recommend an early resample to monitor this condition.
Check Water Access			?	We advise that you check for the source of water entry.

HISTORICAL DIAGNOSIS

12 Aug 2019 Diag: Jonathan Hester

WATER



The oil change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



06 Aug 2019 Diag: Jonathan Hester

WATER




No corrective action is recommended at this time. The oil change at the time of sampling has been noted. Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend







RAL-CFU112A

Component

Gearbox

SUMMIT SYNGEAR PG 460 (--- QTS)

DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We recommend an early resample to monitor this condition.

All component wear rates are normal.

Contamination

There is a high concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Aug	2019	Aug2019 Aug20	Aug2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		RP0033589	RP154373	RP154100	
Sample Date		Client Info		14 Aug 2023	12 Aug 2019	06 Aug 2019	
Machine Age	hrs	Client Info		0	0	0	
Oil Age	hrs	Client Info		0	0	0	
Oil Changed		Client Info		N/A	Changed	Changed	
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>200	13	0	<1	
Chromium	ppm	ASTM D5185m	>15	<1	0	0	
Nickel	ppm	ASTM D5185m	>15	0	<1	0	
Titanium	ppm	ASTM D5185m		<1	0	0	
Silver	ppm	ASTM D5185m		0	0	0	
Aluminum	ppm	ASTM D5185m	>25	<1	<1	0	
Lead	ppm	ASTM D5185m	>100	<1	0	<1	
Copper	ppm	ASTM D5185m	>200	6	<1	<1	
Tin	ppm	ASTM D5185m	>25	<1	0	0	
Antimony	ppm	ASTM D5185m	>5		0	0	
Vanadium	ppm	ASTM D5185m		0	0	0	
Cadmium	ppm	ASTM D5185m		0	0	0	
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		5	<1	<1	
Barium	ppm	ASTM D5185m		0	0	0	
Molybdenum	ppm	ASTM D5185m		0	<1	0	
Manganese	ppm	ASTM D5185m		<1	0	<1	
Magnesium	ppm	ASTM D5185m		<1	<1	0	
Calcium	ppm	ASTM D5185m		18	<1	0	
Phosphorus	ppm	ASTM D5185m		931	168	185	
Zinc	ppm	ASTM D5185m		0	0	<1	
CONTAMINANTS		method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>50	3	<1	<1	
Sodium	ppm	ASTM D5185m		0	1	0	
Potassium	ppm	ASTM D5185m	>20	4	20	<1	
Water	%	ASTM D6304	>0.2	<u> </u>	△ 0.246	△ 0.249	
ppm Water	ppm	ASTM D6304	>2000	<u>\$\text{9210}\$</u>	<u>4</u> 2465.2	△ 2496.3	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2	

1.24

Acid Number (AN)


mg KOH/g ASTM D8045

0.303

0.418



OIL ANALYSIS REPORT







Laboratory Sample No. Lab Number **Unique Number**

: RP0033589 : 05963648 : 10670199 : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : 28 Sep 2023 Received Diagnosed

: 02 Oct 2023 : Jonathan Hester Diagnostician

Test Package Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

HOLLINGSWORTH & VOSE CO

1115 SE CRYSTAL LAKE DR CORVALLIS, OR US 97333

Contact: Jon Ayers jonathan.ayers@hovo.com

T: (541)738-5399

F: x: