


COOLANT REPORT

KANSAS/44 22.70L [KANSAS^44]

Component Coolant

EXTENDED LIFE COOLANT (--- GAL)





Recommendation

No corrective action is recommended at this time. The fluid is suitable for further service.

Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

There is no indication of any contamination in the coolant.


Coolant Condition

Carboxylate test failed. The glycol level is acceptable. The pH level of this fluid is within the acceptable limits.


| | | may2021 | maybob! oupbob! | OUPLOIL MINISOLO | 00)2023 | |
|------------------------|------------|-------------|-----------------|------------------|-------------|-------------|
| SAMPLE INFORM | MATION | method | limit/base | current | history1 | history2 |
| Sample Number | | Client Info | | WC0781178 | WC0673500 | WC0712292 |
| Sample Date | | Client Info | | 22 Sep 2023 | 28 Mar 2023 | 19 Sep 2022 |
| Machine Age | hrs | Client Info | | 5203 | 4764 | 4288 |
| Oil Age | hrs | Client Info | | 5203 | 4764 | 4288 |
| Oil Changed | | Client Info | | Not Changd | Not Changd | Not Changd |
| Sample Status | | | | NORMAL | NORMAL | ABNORMAL |
| PHYSICAL TEST R | RESULTS | method | limit/base | current | history1 | history2 |
| Specific Gravity | | *ASTM D1298 | | 1.066 | 1.065 | 1.063 |
| pH | Scale 0-14 | ASTM D1287 | | 8.24 | 8.13 | 7.97 |
| Nitrites | ppm | AP-053:2009 | | 488 | 636 | 976 |
| Reserve Alkalinity | Scale 0-20 | *ASTM D1121 | | | | |
| Percentage Glycol | % | ASTM D3321 | | 48.8 | 48.5 | 46.2 |
| Freezing Point | °F | ASTM D3321 | | -31 | -31 | -26 |
| Total Dissolved Solids | | | | 388.0 | 422.0 | 122.0 |
| Carboxylate | | | | fail | pass | pass |
| CORROSION INH | IRITORS | method | limit/base | current | history1 | history2 |
| | | | IIIIII/Dase | | | |
| Silicon | ppm | ASTM D6130 | | 10 | 18 | 13 |
| Phosphorus | ppm | ASTM D6130 | | 20 | 60 | 120 |
| Boron | ppm | ASTM D6130 | | 11 | 11 | 0 |
| Molybdenum | ppm | ASTM D6130 | | 402 | 792 | 346 |
| CORROSION | | method | limit/base | current | history1 | history2 |
| Iron | ppm | ASTM D6130 | >15 | 1 | <1 | 0 |
| Aluminum | ppm | ASTM D6130 | >10 | 1 | 2 | 5 |
| Copper | ppm | ASTM D6130 | >10 | 1 | <1 | <1 |
| Lead | ppm | ASTM D6130 | >10 | 1 | <1 | 0 |
| Tin | ppm | ASTM D6130 | >10 | 1 | 0 | 0 |
| Zinc | ppm | ASTM D6130 | | <1 | 0 | 0 |
| CONTAMINANTS | ; | method | limit/base | current | history1 | history2 |
| Chlorine | ppm | ASTM D6130 | | 16 | 23 | 4 |
| CARRIER SALTS | | method | limit/base | current | history1 | history2 |
| Sodium | ppm | ASTM D6130 | | 2940 | 5027 | 2104 |
| Potassium | ppm | ASTM D6130 | | 1385 | 4113 | 3466 |
| SCALE POTENTI | AL | method | limit/base | current | history1 | history2 |
| Calcium | ppm | ASTM D6130 | | 2 | <1 | 0 |
| Magnesium | ppm | ASTM D6130 | | 1 | <1 | <1 |



COOLANT REPORT









Laboratory Sample No. Lab Number Unique Number : 10670447

: WC0781178 : 05963896

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 28 Sep 2023

Diagnosed : 04 Oct 2023 Diagnostician : Jonathan Hester

Test Package : COOL- (Additional Tests: COOL, ICP) Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

SHERWOOD CONSTRUCTION CO INC

3219 WEST MAY ST WICHITA, KS US 67213

Contact: DALE CASINO

dale.casino@sherwood.net T:

F: