

PROBLEM SUMMARY

Sample Rating Trend

ISO


Machine Id **7097185 (S/N 1500)**

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ATTENTION	ABNORMAL	ABNORMAL				
Particles >6µm	ASTM D7647	>1300	2063	▲ 8430					
Particles >14μm	ASTM D7647	>80	<u> </u>	66					
Particles >21µm	ASTM D7647	>20	<u> </u>	5					
Oil Cleanliness	ISO 4406 (c)	>/17/13	20/18/14	22/20/13					

Customer Id: AZIUNI Sample No.: KCPA006411 Lab Number: 05964189 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

27 Mar 2023 Diag: Jonathan Hester

ISO



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



10 Nov 2021 Diag: Doug Bogart

WATER



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend


ISO

7097185 (S/N 1500)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)





DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		No	v2021	Mar2023 Sep20	23	
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA006411	KCP55354	KCP39968
Sample Date		Client Info		25 Sep 2023	27 Mar 2023	10 Nov 2021
Machine Age	hrs	Client Info		10000	7444	4101
Oil Age	hrs	Client Info		0	1000	0
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				ATTENTION	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	5	3	11
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	<1
Barium	ppm	ASTM D5185m	90	0	49	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	100	24	65	2
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	<1	1	0
Zinc	ppm	ASTM D5185m	0	0	9	2
Sulfur	ppm	ASTM D5185m	23500	18866	19939	14057
CONTAMINANTS	S	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	0
Sodium	ppm	ASTM D5185m		6	8	<1
Potassium	ppm	ASTM D5185m	>20	1	0	0
Water	%	ASTM D6304	>0.05	0.012	0.030	△ 0.417
ppm Water	ppm	ASTM D6304	>500	120.8	307.4	<u></u> 4170
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		6052	20300	
Particles >6µm		ASTM D7647	>1300	<u>^</u> 2063	<u>▲</u> 8430	
Particles >14μm		ASTM D7647	>80	<u> </u>	66	
Particles >21μm		ASTM D7647	>20	<u>^</u> 23	5	
Particles >38μm		ASTM D7647	>4	0	0	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/18/14	<u>22/20/13</u>	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2

0.38

0.36

0.296



OIL ANALYSIS REPORT

