


## **PROBLEM SUMMARY**

# RP-101 [10023546082] **B57009 COOKER DISCHARGE**

Component


**Hydraulic System** 


PETRO CANADA PURITY FG HYDRAULIC AW 68 (--- QTS)






## **COMPONENT CONDITION SUMMARY**







## **RECOMMENDATION**

We advise that you check for the source of water entry. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to metal particles present in this sample.

PROBLEMATIC TEST RESULTS									
Sample Status				SEVERE	ATTENTION	ATTENTION			
Iron	ppm	ASTM D5185m	>20	<b>40</b>	24	29			
Water	%	ASTM D6304	>0.05	<b>0.440</b>					
ppm Water	ppm	ASTM D6304	>500	<b>4400</b>					
White Metal	scalar	*Visual	NONE	HEAVY	NONE	NONE			
Visc @ 40°C	cSt	ASTM D445	63.34	<u> </u>	<b>▲</b> 118	<u>109</u>			

Customer Id: HORAUS **Sample No.:** WC0851170 Lab Number: 05964574 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 ihester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Inspect Wear Source			?	We advise that you inspect for the source(s) of wear.			
Change Filter			?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.			
Resample			?	We recommend an early resample to monitor this condition.			
Alert			?	We were unable to perform a particle count due to metal particles present in this sample.			
Check Water Access			?	We advise that you check for the source of water entry.			
Filter Fluid			?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.			

## HISTORICAL DIAGNOSIS

## 09 Jul 2023 Diag: Don Baldridge

VISCOSITY



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The oil viscosity is higher than normal. The AN level is acceptable for this fluid.



## 30 Mar 2023 Diag: Don Baldridge

VISCOSITY



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The oil viscosity is higher than normal. The AN level is acceptable for this fluid.



## 14 Feb 2023 Diag: Don Baldridge

VISCOSITY



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The oil viscosity is higher than normal. The AN level is acceptable for this fluid.





## **OIL ANALYSIS REPORT**

SAMPLE INFORMATION

**FLUID DEGRADATION** 

Acid Number (AN)

mg KOH/g ASTM D8045 0.26

## Sample Rating Trend

## **VISUAL METAL**

# RP-101 [10023546082] **B57009 COOKER DISCHARGE**

**Hydraulic System** 

PETRO CANADA PURITY FG HYDRAULIC AW 68 (--- QTS)

## DIAGNOSIS

#### Recommendation

We advise that you check for the source of water entry. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to metal particles present in this sample.

#### Wear


The iron level is abnormal. High concentration of visible metal present.

#### Contamination

There is a moderate concentration of water present in the oil.

## Fluid Condition

The oil viscosity is higher than normal. The AN level is acceptable for this fluid.



Sample Number		Client Info		WC0851170	WC0826163	WC0765468
Sample Date		Client Info		24 Sep 2023	09 Jul 2023	30 Mar 2023
Machine Age	mths	Client Info		0	0	0
Oil Age	mths	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				SEVERE	ATTENTION	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	<b>40</b>	24	29
Chromium	ppm	ASTM D5185m	>20	0	<1	0
Nickel	ppm	ASTM D5185m	>20	0	0	0
Titanium	ppm	ASTM D5185m	<i>&gt;</i> 20	0	0	0
Silver		ASTM D5105m		0	0	0
	ppm		>20	0	2	0
Aluminum	ppm	ASTM D5185m		-		
Lead	ppm	ASTM D5185m	>20	0	<1	0
Copper	ppm	ASTM D5185m	>20	0	<1	0
Tin	ppm	ASTM D5185m	>20	<1	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	1	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		2	1	<1
Magnesium	ppm	ASTM D5185m		3	0	2
Calcium	ppm	ASTM D5185m		8	0	0
Phosphorus	ppm	ASTM D5185m		425	401	395
Zinc	ppm	ASTM D5185m		29	9	0
Sulfur	ppm	ASTM D5185m		1579	2227	1291
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	2	2	3
Sodium	ppm	ASTM D5185m		2	<1	<1
Potassium	ppm	ASTM D5185m	>20	0	1	0
Water	%	ASTM D6304	>0.05	<b>△</b> 0.440		
ppm Water	ppm	ASTM D6304	>500	<b>4400</b>		
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000		2784	1582
Particles >6µm		ASTM D7647	>2500		741	445
Particles >14μm		ASTM D7647	>320		56	50
Particles >21µm		ASTM D7647	>80		16	14
Particles >38µm		ASTM D7647	>20		1	1
Particles >71µm		ASTM D7647			0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15		19/17/13	18/16/13
		(0)				


0.38

0.41

0.34



## OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No. **Lab Number Unique Number** 

: 05964574

: WC0851170 : 10671125

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received

: 05 Oct 2023 Diagnosed Diagnostician

: Jonathan Hester

: 29 Sep 2023

Test Package : IND 2 (Additional Tests: KF)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**HORMEL FOODS - AUSTIN** 

1101 NORTH MAIN ST AUSTIN, MN US 55912

Contact: RYAN LOWE rslowe@hormel.com T: (507)437-5674

F: (507)437-9805 Contact/Location: RYAN LOWE - HORAUS