




PROBLEM SUMMARY

Sample Rating Trend


ISO

Area
GP-105
 Machine Id
B29774 - VACUUM PUMP BUSCH RA0400 RAPID PAK LINE 1 (S/N C1517)
 Component
Pump
 Fluid
R&O OIL ISO 100 (4 GAL)



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

| Sample Status | | | ABNORMAL | NORMAL | NORMAL |
|-----------------|--------------|-----------|------------|----------|----------|
| Particles >4µm | ASTM D7647 | >10000 | ▲ 38059 | 911 | 1127 |
| Particles >6µm | ASTM D7647 | >1300 | ▲ 12604 | 226 | 315 |
| Particles >14µm | ASTM D7647 | >160 | ▲ 995 | 12 | 32 |
| Particles >21µm | ASTM D7647 | >40 | ▲ 232 | 3 | 11 |
| Oil Cleanliness | ISO 4406 (c) | >20/17/14 | ▲ 22/21/17 | 17/15/11 | 17/15/12 |

Customer Id: HORAUS
 Sample No.: WC0826165
 Lab Number: 05964582
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|---------------|--------|------|---------|---|
| Change Filter | --- | --- | ? | We recommend you service the filters on this component. |

HISTORICAL DIAGNOSIS

25 Apr 2023 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



01 Mar 2023 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



05 Jan 2023 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report






OIL ANALYSIS REPORT

Sample Rating Trend

ISO

Area
GP-105
 Machine Id
B29774 - VACUUM PUMP BUSCH RA0400 RAPID PAK LINE 1 (S/N C1517)
 Component
Pump
 Fluid
R&O OIL ISO 100 (4 GAL)



DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | WC0826165 | WC0791948 | WC0755433 |
| Sample Date | Client Info | | 18 Aug 2023 | 25 Apr 2023 | 01 Mar 2023 |
| Machine Age | yrs | Client Info | 0 | 0 | 0 |
| Oil Age | yrs | Client Info | 0 | 0 | 0 |
| Oil Changed | Client Info | | N/A | N/A | N/A |
| Sample Status | | | ABNORMAL | NORMAL | NORMAL |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|----------|--------|-----------------|----------|----------|----------|
| Iron | ppm | ASTM D5185m >90 | 0 | 2 | 3 |
| Chromium | ppm | ASTM D5185m >5 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m >5 | 0 | 0 | 0 |
| Titanium | ppm | ASTM D5185m >3 | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m >3 | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m >7 | 0 | 0 | <1 |
| Lead | ppm | ASTM D5185m >12 | 0 | 0 | <1 |
| Copper | ppm | ASTM D5185m >30 | 0 | 0 | 0 |
| Tin | ppm | ASTM D5185m >9 | 0 | 0 | 0 |
| Vanadium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | 0 | 0 | 0 |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|--------|------------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185m 5 | 0 | 0 | 0 |
| Barium | ppm | ASTM D5185m 5 | 0 | 0 | <1 |
| Molybdenum | ppm | ASTM D5185m 5 | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | <1 | <1 | 0 |
| Magnesium | ppm | ASTM D5185m 5 | 3 | 16 | 11 |
| Calcium | ppm | ASTM D5185m 5 | 3 | 8 | 11 |
| Phosphorus | ppm | ASTM D5185m 100 | 451 | 24 | 29 |
| Zinc | ppm | ASTM D5185m 25 | 7 | <1 | 9 |
| Sulfur | ppm | ASTM D5185m 1500 | 1117 | 0 | 52 |

CONTAMINANTS

| | method | limit/base | current | history1 | history2 |
|-----------|--------|-----------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185m >60 | 4 | 6 | 8 |
| Sodium | ppm | ASTM D5185m | <1 | 33 | 15 |
| Potassium | ppm | ASTM D5185m >20 | <1 | 4 | 2 |

FLUID CLEANLINESS


| | method | limit/base | current | history1 | history2 |
|-----------------|--------------|------------|-------------------|----------|----------|
| Particles >4µm | ASTM D7647 | >10000 | ▲ 38059 | 911 | 1127 |
| Particles >6µm | ASTM D7647 | >1300 | ▲ 12604 | 226 | 315 |
| Particles >14µm | ASTM D7647 | >160 | ▲ 995 | 12 | 32 |
| Particles >21µm | ASTM D7647 | >40 | ▲ 232 | 3 | 11 |
| Particles >38µm | ASTM D7647 | >10 | 10 | 0 | 1 |
| Particles >71µm | ASTM D7647 | >3 | 1 | 0 | 0 |
| Oil Cleanliness | ISO 4406 (c) | >20/17/14 | ▲ 22/21/17 | 17/15/11 | 17/15/12 |

FLUID DEGRADATION


| | method | limit/base | current | history1 | history2 |
|------------------|----------|-----------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 0.08 | 0.18 | 0.239 | 0.074 |

OIL ANALYSIS REPORT


▲ Particle Trend




▲ Particle Trend



Acid Number




Viscosity @ 40°C



| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >.1 | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG |


| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 | 100 | 96.9 | 112 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0826165 **Received** : 29 Sep 2023
Lab Number : 05964582 **Diagnosed** : 02 Oct 2023
Unique Number : 10671133 **Diagnostician** : Don Baldrige

HORMEL FOODS - AUSTIN
 1101 NORTH MAIN ST
 AUSTIN, MN
 US 55912
 Contact: RYAN LOWE
 rslowe@hormel.com
 T: (507)437-5674
 F: (507)437-9805

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)