PROBLEM SUMMARY

Sample Rating Trend



ISO

Area
MELT SHOP - HYDRAULIC
Machine Id
MELT SHOP TUNDISH FLIPPING STAND
Component
Hydraulic System
Fluid
FIRE-RESISTANT FLUID ISO 46 (275 GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time.
Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				ATTENTION	ATTENTION	NORMAL
Particles >6µm		ASTM D7647	>1300	▲ **1626**	▲ 1635	256
Particles >14µm		ASTM D7647	>160	▲ **277**	▲ 278	44
Particles >21µm		ASTM D7647	>40	▲ **93**	▲ 94	15
Particles >38µm		ASTM D7647	>10	▲ **14**	▲ 14	2
Oil Cleanliness		ISO 4406 (c)	>19/17/14	▲ **19/18/15**	▲ 19/18/15	16/15/13

Customer Id: OUTCALAL
Sample No.: RP0034953
Lab Number: 05964693
Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:
Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

29 Aug 2023 Diag: Doug Bogart

ISO

No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of particulates present in the oil. The pH level of this fluid is within the acceptable limits @ 9.0. The condition of the oil is acceptable for the time in service.

view report

---

26 Jul 2023 Diag: Jonathan Hester

NORMAL

No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The pH level of this fluid is within the acceptable limits at 11.0. The condition of the oil is acceptable for the time in service.

view report

---

28 Jun 2023 Diag: Jonathan Hester

NORMAL

No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The pH level of this fluid is within the acceptable limits at 9.0. The condition of the oil is acceptable for the time in service.

view report

OIL ANALYSIS REPORT

Sample Rating Trend



ISO

Area
MELT SHOP - HYDRAULIC
Machine Id
MELT SHOP TUNDISH FLIPPING STAND
Component
Hydraulic System
Fluid
FIRE-RESISTANT FLUID ISO 46 (275 GAL)

DIAGNOSIS

Recommendation
No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
There is a moderate amount of particulates present in the oil.

Fluid Condition
The pH level of this fluid is within the acceptable limits. pH is 11.0. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**RP0034953**	RP0035571	RP0034893
Sample Date		Client Info		**27 Sep 2023**	29 Aug 2023	26 Jul 2023
Machine Age	hrs	Client Info		**0**	0	0
Oil Age	hrs	Client Info		**0**	0	0
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**ATTENTION**	ATTENTION	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	**0**	0	<1
Chromium	ppm	ASTM D5185m	>20	**0**	0	<1
Nickel	ppm	ASTM D5185m	>20	**0**	0	<1
Titanium	ppm	ASTM D5185m		**0**	0	0
Silver	ppm	ASTM D5185m		**0**	0	0
Aluminum	ppm	ASTM D5185m	>20	**0**	<1	<1
Lead	ppm	ASTM D5185m	>20	**0**	0	0
Copper	ppm	ASTM D5185m	>20	**0**	<1	<1
Tin	ppm	ASTM D5185m	>20	**<1**	<1	<1
Vanadium	ppm	ASTM D5185m		**0**	0	<1
Cadmium	ppm	ASTM D5185m		**0**	0	<1

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	5	**0**	0	0
Barium	ppm	ASTM D5185m	5	**0**	0	1
Molybdenum	ppm	ASTM D5185m	5	**0**	0	0
Manganese	ppm	ASTM D5185m		**0**	0	0
Magnesium	ppm	ASTM D5185m	5	**3**	0	0
Calcium	ppm	ASTM D5185m	50	**2**	3	0
Phosphorus	ppm	ASTM D5185m	175	**3**	15	4
Zinc	ppm	ASTM D5185m	62	**8**	15	7

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	**0**	0	<1
Sodium	ppm	ASTM D5185m		**0**	0	9
Potassium	ppm	ASTM D5185m	>20	**0**	<1	2
Water	%	ASTM D6304	>55	**41.8**	44.4	38.7
ppm Water	ppm	ASTM D6304	>55000	**418000**	444000	387000

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	**2984**	3001	470
Particles >6µm		ASTM D7647	>1300	▲ **1626**	▲ 1635	256
Particles >14µm		ASTM D7647	>160	▲ **277**	▲ 278	44
Particles >21µm		ASTM D7647	>40	▲ **93**	▲ 94	15
Particles >38µm		ASTM D7647	>10	▲ **14**	▲ 14	2
Particles >71µm		ASTM D7647	>3	**1**	1	0
Oil Cleanliness		ISO 4406 (c)	>19/17/14	▲ **19/18/15**	▲ 19/18/15	16/15/13

OIL ANALYSIS REPORT

Particle Trend



Water (KF)



Reserve Alkalinity



Viscosity @ 40°C



Reserve Alkalinity



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Debris	scalar	*Visual	NONE	**LIGHT**	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	NORML	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual	>55	**0.2%**	0.2%	0.2%
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
pH	Scale 0-14	ASTM D1287		**11.0**	9.00	11.0
Visc @ 40°C	cSt	ASTM D445	46	**45.8**	46.8	45.7

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS

Ferrous Alloys



Non-ferrous Metals



Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : RP0034953 **Received** : 29 Sep 2023
Lab Number : 05964693 **Diagnosed** : 03 Oct 2023
Unique Number : 10671244 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: pH, ReserveAlk)

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

OUTOKUMPU STAINLESS USA
HWY 43 N
CALVERT, AL
US 36513
Contact: MARIO JOHNSON
Mario.johnson@outokumpu.com
T: (251)321-4105
F: x: