

# **OIL ANALYSIS REPORT**

KAESER 1228

Component

Compressor

NOT GIVEN (--- GAL)

# Sample Rating Trend

NORMAL

# Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

# Contamination

There is no indication of any contamination in the


# **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Sample Date Client Info 28 Sep 2023	history2
Sample Date Client Info 28 Sep 2023	
Sample Date Client Info 28 Sep 2023	
Machine Age hrs Client Info 0	
Oll oll and a second of the se	
WEAR METALS method limit/base current history1	history2
Iron ppm ASTM D5185m >50 <1	
Chromium ppm ASTM D5185m >10 0	
Nickel ppm ASTM D5185m >3 <b>0</b>	
<b>Titanium</b> ppm ASTM D5185m >3 <b>&lt;1</b>	
<b>Silver</b> ppm ASTM D5185m >2 <b>0</b>	
Aluminum ppm ASTM D5185m >10 2	
Lead ppm ASTM D5185m >10 <b>0</b>	
<b>Copper</b> ppm ASTM D5185m >50 <b>2</b>	
Tin ppm ASTM D5185m >10 <1	
Vanadium ppm ASTM D5185m <b>0</b>	
Cadmium ppm ASTM D5185m <b>0</b>	
ADDITIVES method limit/base current history1	history2
Boron ppm ASTM D5185m <b>0</b>	
Barium ppm ASTM D5185m <b>0</b>	
Molybdenum ppm ASTM D5185m <b>0</b>	
Manganese ppm ASTM D5185m 0	
Magnesium ppm ASTM D5185m <b>39</b>	
Calcium ppm ASTM D5185m 0	
Phosphorus ppm ASTM D5185m 1	
<b>Zinc</b> ppm ASTM D5185m <b>4</b>	
Sulfur         ppm         ASTM D5185m         16008	
CONTAMINANTS method limit/base current history1	history2
Silicon         ppm         ASTM D5185m         >25         <1	
Sodium         ppm         ASTM D5185m         18	
Potassium ppm ASTM D5185m >20 2	
FLUID DEGRADATION method limit/base current history1	history2
Acid Number (AN) mg KOH/g ASTM D8045 0.30	
VISUAL method limit/base current history1	history2
White Metal scalar *Visual NONE NONE	
Yellow Metal scalar *Visual NONE NONE	
Precipitate scalar *Visual NONE NONE	
Silt scalar *Visual NONE NONE	
Debris scalar *Visual NONE NONE	
Sand/Dirt scalar *Visual NONE NONE	
Appearance scalar *Visual NORML NORML	
Odor scalar *Visual NORML NORML	
E 110 1141	
Emulsified Water scalar *Visual >0.05 NEG Free Water scalar *Visual NEG	



# **OIL ANALYSIS REPORT**







Laboratory Sample No. Lab Number

: 05964728 Unique Number : 10671279 Test Package : IND 2

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WC0845136 Received : 29 Sep 2023

Diagnosed : 02 Oct 2023 Diagnostician : Don Baldridge **ELEVATED INDUSTRIAL SOLUTIONS - EIS** 

302 HUGHES ST FOUNTAIN INN, SC US 29644

Contact: DARRIN WARD

dward@elevatedindustrial.com

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: DARRIN WARD - PALFOU

F: (864)862-7653