




OIL ANALYSIS REPORT

Sample Rating Trend



Area
EDLCOV
Machine Id
COVM01BL
Component
Biogas Engine
Fluid
CHEVRON HDAX 6500 LFG GAS ENGINE OIL (141 GAL)

DIAGNOSIS

Recommendation
We recommend that you drain the oil and perform a filter service on this component if not already done. We recommend an early resample to monitor this condition.

Wear
All component wear rates are normal.

Contamination
Elemental level of silicon (Si) above normal indicating ingress of seal material.

Fluid Condition
The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0853583	WC0853576	WC0816091
Sample Date	Client Info		26 Sep 2023	21 Sep 2023	24 Aug 2023
Machine Age	hrs	Client Info	125038	124913	124751
Oil Age	hrs	Client Info	1077	952	790
Oil Changed	Client Info		Not Chngd	Not Chngd	Not Chngd
Sample Status			SEVERE	ABNORMAL	ABNORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>15	5	4	3
Chromium	ppm	ASTM D5185m	>4	<1	<1	0
Nickel	ppm	ASTM D5185m	>2	<1	1	0
Titanium	ppm	ASTM D5185m		<1	0	<1
Silver	ppm	ASTM D5185m	>5	0	0	0
Aluminum	ppm	ASTM D5185m	>6	4	3	2
Lead	ppm	ASTM D5185m	>9	2	2	2
Copper	ppm	ASTM D5185m	>6	3	2	2
Tin	ppm	ASTM D5185m	>4	3	3	2
Vanadium	ppm	ASTM D5185m		0	0	<1
Cadmium	ppm	ASTM D5185m		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		7	7	7
Barium	ppm	ASTM D5185m		0	2	0
Molybdenum	ppm	ASTM D5185m		8	5	8
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		42	34	41
Calcium	ppm	ASTM D5185m		1804	1767	1924
Phosphorus	ppm	ASTM D5185m		311	283	316
Zinc	ppm	ASTM D5185m		381	371	377
Sulfur	ppm	ASTM D5185m		2028	2167	2336

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>181	216	200	188
Sodium	ppm	ASTM D5185m		11	9	15
Potassium	ppm	ASTM D5185m	>20	0	1	0

INFRA-RED





	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844		0	0	0
Nitration	Abs/cm	*ASTM D7624	>20	6.0	5.8	5.5
Sulfation	Abs.1mm	*ASTM D7415	>30	18.1	17.7	17.0

FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs.1mm	*ASTM D7414	>25	12.4	11.3	10.4
Acid Number (AN)	mg KOH/g	ASTM D8045	1.2	1.14	1.16	0.949
Base Number (BN)	mg KOH/g	ASTM D2896	4.5	4.68	4.96	5.46











OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	14.7	13.7	13.6

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0853583 **Received** : 29 Sep 2023
Lab Number : 05964760 **Diagnosed** : 02 Oct 2023
Unique Number : 10671311 **Diagnostician** : Sean Felton
Test Package : MOB 2

EDL NA Recips-Covel
 COVEL GARDENS POWER STATION, 8611 COVEL ROAD
 SAN ANTONIO, TX
 US 78252
 Contact: ARIEL CARRION
 ariel.carrion@edlenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: