




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
IBACO [CONHER]
Machine Id
BM ISMAR 8 MAIN ENGINE
Component
Auxiliary Auxiliary Engine
Fluid
XTRA REV 15W40 (8 LTR)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

Fuel content negligible. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		KL0012880	KL0011415	KL0010127
Sample Date	Client Info		20 Sep 2023	06 Apr 2023	03 Oct 2022
Machine Age	hrs	Client Info	15718	15618	13014
Oil Age	hrs	Client Info	100	240	250
Oil Changed	Client Info		Changed	Not Changd	Not Changd
Sample Status			NORMAL	ABNORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >100	8	25	39
Chromium	ppm	ASTM D5185m >20	<1	<1	2
Nickel	ppm	ASTM D5185m >2	0	0	4
Titanium	ppm	ASTM D5185m >2	<1	0	<1
Silver	ppm	ASTM D5185m >2	0	0	0
Aluminum	ppm	ASTM D5185m >20	3	<1	6
Lead	ppm	ASTM D5185m >40	1	1	5
Copper	ppm	ASTM D5185m >330	2	1	2
Tin	ppm	ASTM D5185m >15	<1	<1	2
Vanadium	ppm	ASTM D5185m	0	0	<1
Cadmium	ppm	ASTM D5185m	0	0	<1

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	4	83
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	<1	3	84
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m	6	19	402
Calcium	ppm	ASTM D5185m	2674	3185	2071
Phosphorus	ppm	ASTM D5185m	1102	1203	969
Zinc	ppm	ASTM D5185m	1367	1602	1247
Sulfur	ppm	ASTM D5185m	3655	3757	3600

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	10	7	16
Sodium	ppm	ASTM D5185m	<1	1	15
Potassium	ppm	ASTM D5185m >20	<1	3	24
Fuel	%	ASTM D3524 >4.0	1.3	▲ 7.2	<1.0

INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0	0.2	0.3
Nitration	Abs/cm	*ASTM D7624 >20	6.1	12.5	15.4
Sulfation	Abs/.1mm	*ASTM D7415 >30	13.8	19.2	27.9



OIL ANALYSIS REPORT








FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		1757	11275	4187
Particles >6µm	ASTM D7647	>5000	957	▲ 6142	2281
Particles >14µm	ASTM D7647	>640	163	▲ 1045	388
Particles >21µm	ASTM D7647	>160	55	▲ 352	131
Particles >38µm	ASTM D7647	>40	8	▲ 54	20
Particles >71µm	ASTM D7647	>10	1	6	2
Oil Cleanliness	ISO 4406 (c)	>19/16	17/15	▲ 20/17	18/16

FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs./1mm *ASTM D7414	>25	8.2	17.7	31.3
Base Number (BN)	mg KOH/g ASTM D2896		9.67	12.31	7.35

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar *Visual	NONE	NONE	LIGHT	NONE
Yellow Metal	scalar *Visual	NONE	NONE	NONE	NONE
Precipitate	scalar *Visual	NONE	NONE	NONE	NONE
Silt	scalar *Visual	NONE	NONE	NONE	NONE
Debris	scalar *Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar *Visual	NONE	NONE	NONE	NONE
Appearance	scalar *Visual	NORML	NORML	NORML	NORML
Odor	scalar *Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar *Visual	>0.1	NEG	NEG	NEG
Free Water	scalar *Visual		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt ASTM D445		12.8	▲ 10.7	15.4

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KL0012880 **Received** : 29 Sep 2023
Lab Number : 05964782 **Diagnosed** : 03 Oct 2023
Unique Number : 10671333 **Diagnostician** : Angela Borella
Test Package : MOB 2 (Additional Tests: PercentFuel, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

CONOR
 JUAREZ 348
 HERMOSILLO,
 MX 83140
 Contact: EDUARDO GARCIA
 egarcia.comsa@gmail.com

T: (526)622-1581 x:81

F: x: