




PROBLEM SUMMARY

Area
COMPOUND
 Machine Id
3-DR MIXER - AGITATOR
 Component
Gearbox
 Fluid
SHELL OMALA S4 WE 460 (0 GAL)

Sample Rating Trend



SEDIMENT



COMPONENT CONDITION SUMMARY

No relevant graphs to display


RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
Silt	scalar	*Visual	NONE	▲ HEAVY	NONE	NONE

Customer Id: LUBGAS
Sample No.: WC0855206
Lab Number: 05965331
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component if applicable.
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS

29 Jun 2023 Diag: Don Baldrige

WEAR



We recommend you service the filters on this component if applicable. We recommend an early resample to monitor this condition. Bearing and/or bushing wear is indicated. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



30 Mar 2023 Diag: Doug Bogart

ISO



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



30 Dec 2022 Diag: Jonathan Hester

WEAR



We recommend you service the filters on this component if applicable. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition. Bearing and/or bushing wear is indicated. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



SEDIMENT



Area
COMPOUND
 Machine Id
3-DR MIXER - AGITATOR
 Component
Gearbox
 Fluid
SHELL OMALA S4 WE 460 (0 GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

There is a high amount of visible silt present in the sample.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0855206	WC0741890	WC0802655
Sample Date	Client Info		28 Sep 2023	29 Jun 2023	30 Mar 2023
Machine Age	mths	Client Info	0	0	0
Oil Age	mths	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >200	6	8	0
Chromium	ppm	ASTM D5185m >15	0	<1	0
Nickel	ppm	ASTM D5185m >15	<1	1	0
Titanium	ppm	ASTM D5185m	<1	<1	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	<1	0	0
Lead	ppm	ASTM D5185m >100	3	<1	<1
Copper	ppm	ASTM D5185m >200	190	▲ 230	13
Tin	ppm	ASTM D5185m >25	22	▲ 30	<1
Vanadium	ppm	ASTM D5185m	0	<1	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	10	4	0
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	<1	<1
Manganese	ppm	ASTM D5185m	0	<1	<1
Magnesium	ppm	ASTM D5185m	5	2	<1
Calcium	ppm	ASTM D5185m	3	4	2
Phosphorus	ppm	ASTM D5185m	462	448	409
Zinc	ppm	ASTM D5185m	41	19	0
Sulfur	ppm	ASTM D5185m	326	205	0

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	9	7	5
Sodium	ppm	ASTM D5185m	0	0	0
Potassium	ppm	ASTM D5185m >20	5	3	3

FLUID CLEANLINESS



	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	---	▲ 302925	▲ 309366
Particles >6µm	ASTM D7647	>5000	---	▲ 255537	▲ 110026
Particles >14µm	ASTM D7647	>640	---	▲ 53604	▲ 1713
Particles >21µm	ASTM D7647	>160	---	▲ 5314	▲ 357
Particles >38µm	ASTM D7647	>40	---	▲ 52	▲ 45
Particles >71µm	ASTM D7647	>10	---	4	4
Oil Cleanliness	ISO 4406 (c)	>21/19/16	---	▲ 25/25/23	▲ 25/24/18

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.056	0.092	0.257




OIL ANALYSIS REPORT






VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	▲ HEAVY	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	460	489	481	473

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : WC0855206 Received : 29 Sep 2023
 Lab Number : 05965331 Diagnosed : 02 Oct 2023
 Unique Number : 10671882 Diagnostician : Don Baldrige
 Test Package : IND 2 (Additional Tests: PrtCount)

LUBRIZOL ADVANCED MATERIALS INC
 207 TELEGRAPH DR
 GASTONIA, NC
 US 28056
 Contact: TIMOTHY DAVIS
 timothy.davis@lubrizol.com
 T: (704)915-4131
 F: x:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)