




PROBLEM SUMMARY


Area
ACRYLIC
 Machine Id
RX 4 - AGITATOR
 Component
Gearbox
 Fluid
SHELL OMALA S2 G 220 (7 GAL)

Sample Rating Trend



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

No corrective action is recommended at this time.
 Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status		ABNORMAL	ABNORMAL	ABNORMAL
Particles >4µm	ASTM D7647 >20000	▲ 66993	▲ 102353	---
Oil Cleanliness	ISO 4406 (c) >21/19/16	▲ 23/19/14	▲ 24/20/13	---

Customer Id: LUBGAS
 Sample No.: WC0855212
 Lab Number: 05965332
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

27 Mar 2023 Diag: Doug Bogart

ISO



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



27 Sep 2022 Diag: Don Baldrige

WATER



We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count. All component wear rates are normal. Appearance is milky. There is a high concentration of water present in the oil. Free water present. The AN level is acceptable for this fluid.

view report



28 Mar 2022 Diag: Jonathan Hester

WATER



We advise that you check for the source of water entry. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 6 microns in size) present in the oil. There is a moderate concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
ACRYLIC
Machine Id
RX 4 - AGITATOR

Component
Gearbox
Fluid
SHELL OMALA S2 G 220 (7 GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 6 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0855212	WC0802649	WC0741883
Sample Date	Client Info	22 Sep 2023	27 Mar 2023	27 Sep 2022
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	36512
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >200	137	134	146
Chromium	ppm	ASTM D5185m >15	<1	<1	<1
Nickel	ppm	ASTM D5185m >15	0	0	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	<1	0	1
Lead	ppm	ASTM D5185m >100	0	0	6
Copper	ppm	ASTM D5185m >200	<1	0	4
Tin	ppm	ASTM D5185m >25	0	0	<1
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 4.4	0	1	<1
Barium	ppm	ASTM D5185m 0.0	0	0	0
Molybdenum	ppm	ASTM D5185m 0	0	<1	0
Manganese	ppm	ASTM D5185m	2	2	2
Magnesium	ppm	ASTM D5185m 0	12	12	8
Calcium	ppm	ASTM D5185m 0	6	8	13
Phosphorus	ppm	ASTM D5185m 215	299	343	285
Zinc	ppm	ASTM D5185m 0	3	0	19
Sulfur	ppm	ASTM D5185m 7039	11317	15428	13051

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >50	2	2	3
Sodium	ppm	ASTM D5185m	2	1	0
Potassium	ppm	ASTM D5185m >20	0	2	0

FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >20000	▲ 66993	▲ 102353	---
Particles >6µm	ASTM D7647 >5000	4497	▲ 5192	---
Particles >14µm	ASTM D7647 >640	138	67	---
Particles >21µm	ASTM D7647 >160	28	11	---
Particles >38µm	ASTM D7647 >40	0	0	---
Particles >71µm	ASTM D7647 >10	0	0	---
Oil Cleanliness	ISO 4406 (c) >21/19/16	▲ 23/19/14	▲ 24/20/13	---


FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.44	0.44	0.42




OIL ANALYSIS REPORT


▲ Particle Trend




▲ Particle Trend



Acid Number



Viscosity @ 40°C




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	▲ MILKY
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	▲ 0.2%
Free Water	scalar	*Visual		NEG	▲ 2.0

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	220	216	217

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------


Color




Bottom

GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : WC0855212 Received : 29 Sep 2023
 Lab Number : 05965332 Diagnosed : 04 Oct 2023
 Unique Number : 10671883 Diagnostician : Jonathan Hester
 Test Package : IND 2 (Additional Tests: PrtCount)

LUBRIZOL ADVANCED MATERIALS INC
 207 TELEGRAPH DR
 GASTONIA, NC
 US 28056
 Contact: TIMOTHY DAVIS
 timothy.davis@lubrizol.com
 T: (704)915-4131
 F: x:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)