


PROBLEM SUMMARY

Machine Ic GARDNER DENVER NORTH GD (S/N S623236) Component

Air Compressor Fluic AEON 6000FG-46 (--- GAL)

COMPONENT CONDITION SUMMARY



No relevant graphs to display

RECOMMENDATION	PROBLEMATIC TEST RESULTS		
Ma waaawaa aa uu aa aa iyo dha filtawa ay thia	Sample Status	NORMAI	ABNORMAL

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMAT	IC TEST RE	SULTS				
Sample Status				ABNORMAL	NORMAL	ABNORMAL
Debris	scalar	*Visual	NONE	🔺 MODER	NONE	LIGHT

Customer Id: CAVHER Sample No.: USP0001778 Lab Number: 05965416 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED A	CTIONS			
Action	Status	Date	Done By	Description
Change Filter			?	We recommend you service the filters on this component.
Alert			?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS



07 Jun 2023 Diag: Doug Bogart

Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



28 Feb 2023 Diag: Doug Bogart



We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of silt (particulates < 6 microns in size) present in the oil. Free water present. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

13 Dec 2022 Diag: Doug Bogart



We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report





OIL ANALYSIS REPORT

Sample Number

Particles >71µm

Oil Cleanliness

Acid Number (AN)

FLUID DEGRADATION

Sample Date

Machine Ic GARDNER DENVER NORTH GD (S/N S623236) Component

Air Compressor Fluic

AEON 6000FG-46 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear


All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Campie Date				20 000 2020	07 0011 2020	201002020
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	0
Chromium	ppm	ASTM D5185m	>4	0	0	0
Nickel	ppm	ASTM D5185m	>4	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	0
Lead	ppm	ASTM D5185m	>20	0	0	0
Copper	ppm	ASTM D5185m	>40	0	<1	0
Tin	ppm	ASTM D5185m	>5	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m		4	0	0
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		253	228	303
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m		312	382	51
CONTAMINANT	S	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	<1
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	0	0	0
Water	%	ASTM D6304	>0.6	0.060	0.004	0.145
ppm Water	ppm	ASTM D6304	>6000	608.3	44.9	1450
FLUID CLEANLI	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000		3798	🔺 13110
Particles >6µm		ASTM D7647	>2500		991	1686
Particles >14µm		ASTM D7647	>320		70	16
Particles >21µm		ASTM D7647	>80		17	3
Particles >38µm		ASTM D7647	>20		1	1

ASTM D7647 >4

>20/18/15

limit/base

ISO 4406 (c)

method

mg KOH/g ASTM D8045

Contact/Location: HARRY RADLOFF - CAVHER

0.18

0

19/17/13

history1

0.19

current

0

0.17


21/18/11

history2



Feb15/22

OIL ANALYSIS REPORT




VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	🔺 MODER	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.6	NEG	NEG	0.2%
Free Water	scalar	*Visual		NEG	NEG	▲ 1.0
FLUID PROPER	TIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		66.0	66.1	50.34
SAMPLE IMAGES		method	limit/base	current	history1	history2

Color



Bottom



Contact/Location: HARRY RADLOFF - CAVHER