




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
RIG 6
Machine Id
R6-G-02 NKL
Component
Diesel Engine
Fluid
NOT GIVEN (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			KL0012961	KL0012689	KL0012526
Sample Date	Client Info			17 Sep 2023	28 Jul 2023	24 Jun 2023
Machine Age	days	Client Info		45180	45134	45099
Oil Age	days	Client Info		0	0	0
Oil Changed	Client Info			N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Fuel	WC Method	>5		<1.0	<1.0	<1.0
Glycol	WC Method			NEG	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>100	2	6	5
Chromium	ppm	ASTM D5185m	>20	0	<1	<1
Nickel	ppm	ASTM D5185m	>4	0	<1	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>20	7	5	3
Lead	ppm	ASTM D5185m	>40	0	0	1
Copper	ppm	ASTM D5185m	>330	0	2	1
Tin	ppm	ASTM D5185m	>15	0	0	<1
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		429	340	393
Barium	ppm	ASTM D5185m		0	<1	0
Molybdenum	ppm	ASTM D5185m		127	128	134
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m		693	645	737
Calcium	ppm	ASTM D5185m		1559	1519	1694
Phosphorus	ppm	ASTM D5185m		707	676	758
Zinc	ppm	ASTM D5185m		858	849	913
Sulfur	ppm	ASTM D5185m		2540	2728	3149


CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	11	9	14
Sodium	ppm	ASTM D5185m		<1	6	2
Potassium	ppm	ASTM D5185m	>20	0	2	2

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	>3	0.1	0.1	0.2
Nitration	Abs/cm	*ASTM D7624	>20	5.1	5.4	7.0
Sulfation	Abs/.1mm	*ASTM D7415	>30	21.6	22.8	23.5




OIL ANALYSIS REPORT


Particle Trend




Base Number



Viscosity @ 100°C



Particle Trend



FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	3550	5020	3280
Particles >6µm	ASTM D7647	>5000	1934	2735	1787
Particles >14µm	ASTM D7647	>640	329	465	304
Particles >21µm	ASTM D7647	>160	111	157	102
Particles >38µm	ASTM D7647	>40	17	24	16
Particles >71µm	ASTM D7647	>10	2	2	2
Oil Cleanliness	ISO 4406 (c)	>21/19/16	19/18/16	20/19/16	19/18/15


FLUID DEGRADATION	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414	>25	14.8	15.9	17.2
Base Number (BN)	mg KOH/g	ASTM D2896	9.03	11.64	13.31	

VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	NONE	NONE	
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
Precipitate	scalar	*Visual	NONE	NONE	NONE	
Silt	scalar	*Visual	NONE	NONE	NONE	
Debris	scalar	*Visual	NONE	NONE	NONE	
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
Appearance	scalar	*Visual	NORML	NORML	NORML	
Odor	scalar	*Visual	NORML	NORML	NORML	
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.9	13.9	14.0

GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 100°C



Particle Count



Base Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KL0012961 **Received** : 29 Sep 2023
Lab Number : **05965528** **Diagnosed** : 04 Oct 2023
Unique Number : 10672079 **Diagnostician** : Jonathan Hester
Test Package : MOB 2 (Additional Tests: PrtCount)

CITADEL DRILLING
 7550 W I20
 ODESSA, TX
 US 79763

Contact: MIKE COMBDEN
 mcombden@citadelldrilling.com

T: (780)955-5509

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)